



C/83

  
75  
Azadi Ka  
Amrit Mahotsav

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/School/2025/SZ/ 152

Dated: 13 / 03 / 2025

To

The Principal,  
Delhi International School,  
(Great Harsh Educational welfare & Charitable Society)  
Sector-18, Dwarka Phase-II, New Delhi.

**Sub: Renewal of Fire Safety Certificate in r/o Delhi International School (Great Harsh Educational welfare & Charitable Society), Sector-18, Dwarka Phase-II, New Delhi.**

Sir,

Please refer to your letter No. DISE/2024-25/175 received through outdoor diary No. 12215 dated 07/02/2025, on the subject cited above. In this connection, it is to inform you that the premise was re-visited by the officer concerned of this department on 13/02/2025 in the presence of Sh. Naresh Kumar (Transport In-charge) to verify the compliance of shortcomings communicated vide letter No. F.6/DFS/MS/School/2025/SZ/35 dated 15/01/2025 and the status of shortcomings observed is as below.

S. No.	Shortcomings communicated	Present status
1.	Electrical shaft found un-sealed.	Complied
2.	Hose reel hose & hydrants found non-functional.	Complied
3.	Terrace pump found non-functional.	Complied
4.	Exit signage's & Lift signage's found removed.	Complied
5.	Alarm system in lift car found non-functional.	Not complied
6.	LPG cylinder found stored in laboratory	Complied
7.	The courtyard shown in the approved plans is open to sky. Whereas, it has been covered now by temporary sheet.	Not complied

In view of the above shortcomings renewal of Fire Safety Certificate is rejected & you are advised to comply with the remaining shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR

T. No. 011-23414000

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054