



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ/ 420

Dated: 21 / 05 / 2025

To

The Authorised Signatory,
Delhi International School Edge,
(Great Harsh Educational Welfare & Charitable Society)
Sector-18, Dwarka Phase -II, New Delhi.

Sub: Renewal of Fire Safety Certificate in r/o Delhi International School (Great Harsh Educational Welfare & Charitable Society) at Sector-18, Dwarka Phase-II, New Delhi-110075

Sir,

Please refer to your letter No. DISE/2025-26/01 dated 01/04/2025 received in this department vide outdoor diary No. 268 dated 07/04/2025. In this connection, the school premise was re-visited by the officer concerned of this department on 07/05/2025 in the presence of Sh. Naresh Kumar (Transport Incharge) to verify the compliance of shortcomings issued vide this office letter No. F6/DFS/MS/School/2025/SZ/152 dated 13/03/2025 and observed that the shortcoming mentioned at serial no. 7 (seven) has not yet been complied.

In view of above, application for renewal of fire safety certificate cannot be considered at this stage. You are advised to rectify the left-over shortcomings under intimation to this department for further action.

Yours faithfully,

(ATUL GARG)
DIRECTOR

Ph. 011-23414000

21/05/25



C/83

75
Azadi Ka
Amrit Mahotsav**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/School/2025/SZ/ 152

Dated: 13 / 03 / 2025

To

The Principal,
Delhi International School,
(Great Harsh Educational welfare & Charitable Society)
Sector-18, Dwarka Phase-II, New Delhi.

Sub: Renewal of Fire Safety Certificate in r/o Delhi International School (Great Harsh Educational welfare & Charitable Society), Sector-18, Dwarka Phase-II, New Delhi.

Sir,

Please refer to your letter No. DISE/2024-25/175 received through outdoor diary No. 12215 dated 07/02/2025, on the subject cited above. In this connection, it is to inform you that the premise was re-visited by the officer concerned of this department on 13/02/2025 in the presence of Sh. Naresh Kumar (Transport In-charge) to verify the compliance of shortcomings communicated vide letter No. F.6/DFS/MS/School/2025/SZ/35 dated 15/01/2025 and the status of shortcomings observed is as below.

S. No.	Shortcomings communicated	Present status
1.	Electrical shaft found un-sealed.	Complied
2.	Hose reel hose & hydrants found non-functional.	Complied
3.	Terrace pump found non-functional.	Complied
4.	Exit signage's & Lift signage's found removed.	Complied
5.	Alarm system in lift car found non-functional.	Not complied
6.	LPG cylinder found stored in laboratory	Complied
7.	The courtyard shown in the approved plans is open to sky. Whereas, it has been covered now by temporary sheet.	Not complied ✓

In view of the above shortcomings renewal of Fire Safety Certificate is rejected & you are advised to comply with the remaining shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,


(ATUL GARG)
DIRECTOR

T. No. 011-23414000

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054