



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



C-93

No. F.6/DFS/MS/School/2025/SZ/ 974

Dated: 11/08/2025

**FIRE SAFETY CERTIFICATE**

Certified that the building of **Delhi International School Edge** located at Sector-18, Dwarka Phase-II, New Delhi-110075, comprised of **Ground plus three upper floors**, owned/occupied by Great Harsh Educational Welfare & Charitable Society, was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/SZ/2021/639 dated 24/08/2021. The premise was re-inspected by the officer concerned of this department on dated 17/07/2025 in the presence of Sh. Naresh Kumar (Transport In-charge) and found that said **premises/building is fit for occupancy class "Educational Group B"** (School) with effect from 11/08/2025 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 11/08/2025 at New Delhi by

  
(Virendra Singh)  
Chief Fire Officer  
Delhi Fire Service  
01/8/25

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054
2. Authorized Signatory, Delhi International School located at Sector-18, Dwarka Phase-II, New Delhi-110075
3. The Chairman, DDA, Vikas Sadan, INA, New Delhi.

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
5. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, prior to its expiry.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The building sanctioning authority may verify the authorization of covered courtyard, however, the same has been protected with smoke venting arrangements.



N-29

## INSPECTION REPORT

1.	Name & address of the building	Delhi International School Edge (Great Harsh Educational Welfare & Charitable Society) located at Sector-18, Dwarka Phase-II, New Delhi-110075		
2.	Type of Occupancy	Educational (Ground + 3 Upper Floor)		
3.	Type of Case	Renewal		
4.	Details of previous NOC	F6/DFS/MS/SZ/2021/639 dated 24/08/2021		
5.	Fire Safety Directives Letter No.	DOE Circular 3298 -3398 Dated 01/03/2011		
6.	Date of Inspection	17/07/2025		
7.	Name of the Inspecting Officer	DO (SW) and ADO (DWK)		
8.	Name and designation of Officer from the building side	Sh. Naresh Kumar (Transport In-charge)		
9.	Year of Construction	2015		
10.	Applicant's letter No.	DISE/2025-26/29 dated 27/06/2025 Outdoor Diary No. 3172 dated 27/06/2025.		
S. No	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	Provided	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	04 Nos	04 Nos	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.5 mtr	3x1.5m, 1x 2.17m	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	03 Nos	Provided	MR
	e. Width Of Corridor	1.5 mtr	2.1 mtr	MR
	f. Door Size	1 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	12 ACPH	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	17 Nos	18 Nos	MR
	• Types	CO <sub>2</sub> & WCO <sub>2</sub>	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	03 Nos	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR



N-25

7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants:			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements:			
	• Ground Level			
	➤ Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	35m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 ltr	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	DG Set	MR
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	NA	NA	NA

SP 4

19.	Fire Control Room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	N/A	ABC type fire extinguisher provided near electric panel	N/A

Note: The open to sky courtyard covered with temporary sheet has been provided with smoke venting arrangements. However, building sanctioning authority may verify the authorization of covered courtyard, if agreed please.

The fire protection systems provided in the building were test checked and found functional at the time of inspection. The shortcomings communicated by this department vide letter No. F6/DFS/MS/School/2025/SZ/152 dated 13/03/2025 have been complied, from fire safety point of view.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, the fire safety certificate issued vide letter No. F6/DFS/MS/SZ/2021/639 dated 24/08/2021, **renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.**

Accordingly, reply letter is put up for perusal/approval & signature please.

24/7/25  
Signature of the Inspecting Officer  
Name: Rajinder Atwal  
Designation: DO (SW)

24/7/25  
Signature of the Inspecting Officer  
Name: Santosh Kumar  
Designation: ADO (DWK)

CFO/HO

9/8/2025  
Principal Director

Cfo to Gen.  
Cfo / 9/8/25

ADO (DWK)

Sir, FT Utkar is printed for your kind info.

CFO/HO

9/8/2025

MS

9/8/25