



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/School/2025/SZ/ 35

Dated: 15 / 01 / 2025

To

The Principal,  
Delhi International School,  
(Great Harsh Educational welfare & Charitable Society)  
Sector-18, Dwarka Phase-II, New Delhi.

**Sub: Renewal of Fire Safety Certificate in r/o Delhi International School (Great Harsh Educational welfare & Charitable Society), Sector-18, Dwarka Phase-II, New Delhi.**

Sir,

Please refer to your letter No. DISE/2024-25/147 dated 02/12/2024 on the subject cited above. In this connection, it is to inform you that the premise was inspected by the officer concerned of this department on 03/01/2025 in the presence of Sh. Naresh Kumar (Transport In-charge) from fire safety point of view. During course of inspection, the shortcomings observed are as below.

1. Electrical shaft found un-sealed.
2. Hose reel hose & hydrants found non functional
3. Terrace pump found non-functional.
4. Exit signage's & Lift signage's found removed.
5. Alarm system in lift car found non-functional.
6. LPG cylinder found stored in laboratory.
7. The courtyard shown in the approved plans is open to sky. Whereas, it has been covered now by temporary sheet.

In view of the above shortcomings renewal of Fire Safety Certificate is rejected. & you are directed to comply the shortcomings under intimation to this department for further consideration in the matter.

(ATUL GARG)  
DIRECTOR

T. No. 011-23414000

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054