

e-125

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2025 01

Dated: 06/01/2025

To,

Dr. N. Malati
Delhi Institute of Advanced Studies,
Plot No-6, Sec-25,
Delhi-110085.

Sub: Renewal of FSC in r/o Delhi Institute of Advanced Studies, Plot No-6, Sec-25, Delhi-110085.

Sir,

Kindly reference to online mail dated 04.11.2024, received in this department on the subject cited above. In this connection it is to inform you that the shortcoming already issued by this department letter of even No. 348 dated 22.10.2024 (Copy enclosed). & the status of shortcoming is as follows;

1. Terrace fire pumps were not found in auto mode. **(Rectified)**
2. Staircase at terrace found altered and alternate exit is not accessible. **(Not Rectified)**

Therefore, you are advised to submit compliance of all the shortcomings issued vide this department letter dated 22.10.2024 for further consideration in this matter.

Yours Faithfully

(Atul Garg)

DIRECTOR

Ph; 011-23414000