

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

Dated: 10 / 07 / 2025

No.F6/DFS/MS/NDZ/School/2025/ 583

To

The Principal,  
 Delhi M. C. P. Co-Ed. School,  
 Neem Wali Gali, Azad Mkt.,  
 Nawab Ganj, Delhi - 110006.

**Sub: - Regarding issuance of "Fire Safety Certificate" from fire safety point of view in r/o Delhi M. C. P. Co-Ed. School located at Neem Wali Gali, Azad Mkt. Nawab Ganj, Delhi - 110006.**

Sir,

This has reference to letter outdoor diary No. 2177 dated 28.05.2025 received in this department, on the subject cited above. In this connection, this is to inform you that the school building was visited by the officer concerned from this department on 01.07.2025 in the presence of Mr. Raj Kumar (Security Guard) and observed that the building is comprised of ground + 01 upper floor. During inspection following shortcomings were observed:

1. The school is not accessible to fire engines as approach road width is less than 06 mtrs.
2. One more additional staircase is required having width not less than 0.75 m.
3. Exit signages are not provided.

In view of the above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management.

Yours faithfully,

  
 (Atul Garg)

Director  
 Delhi Fire Service  
 Tel: 011-23414000

o/c  
 8/7  
 047

**Copy to:-**

The Director of Education,  
 Govt. of NCT of Delhi, Old Secretariat, Delhi.