

100

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE NEW DELHI- 110 001

No.F6/DFS/MS/Metro/2025/NDZ/ 478

Dated: 10/09/12-25

FIRE SAFETY CERTIFICATE

Issued on 10/09/20 10/09/20 at New Delhi by

(VIRENDRA SINGH)

OC CHIEF FIRE OFFICER

To:-

 Sr. DGM/E&M Metro Bhawan, Fire Brigade Lane, New Delhi 110001

Dy. General Manager/Elect/PD
 Ashoka Road, Near Patel Chowk Metro Station), Delhi-110001

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.

2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency.

3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.

4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.

5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.

6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

N/27

1. Name & address of the building

2. Building is comprised of

3. Type of Occupancy

4. Type of Case

5. Details of Previous NOC letter

6. Fire Safety directive letter No.

7. /Date of Inspection

8. Name of the Inspecting officers

Name and designation of officer from the building side

10. Year of construction

11. Applicant's letter No

: DMRC IT Park Block No.2

Shastri Park, Delhi

:Two basement plus ground plus eight upper floors

:Business Building

:Renewal

:F6/DFS/MS/2022/NDZ/313 dated 15/07/2022

:F.6/MS/DFS/BP/2006/1733 Dated 27/07/2006

:25/08/2025

: ADO(Shd.) Deepak Kumar

:Sh. Himanshu Bhardwaj (Estate Manger)

:2006

:DMRC/GM/PD-I/ITP/DFS/202/2086 dt.22/07/2025

| Sr. No. | Minimum Standards on Fire Prevention and Fire Safety U/R33 | Directives Requirements | Provided at Site | Remarks MR/NMR | |
|------------|------------------------------------------------------------------|----------------------------|---------------------------|-------------------|--|
| 01 | Access to Building. | | | | |
| | Road width | 12mtr. | 30mtr. | MR | |
| | Gate width | 4.50mtr. | 06 mtr. | MR | |
| | Width of internal road | 06 mtr. | 06 mtr. | MR | |
| 02 | Number, Width, Type and Arranger | 0 | | | |
| | a. Number of Staircases | | | 1 20/2020 | |
| | Upper floor | 05 nos. | 05nos. | MR | |
| | Basement | 05 nos. | 08nos | MR | |
| | B. Width of Staircases | | 4 COunty apply | MR | |
| | Upper floor | 1.25mtr. | 1.50mtr. each | MR | |
| | Basement | 1.25 mtr. | 1.50mtr. each& 01 ramp | IVIIX | |
| | c. Protection of Exits | Domition | Provided | MR | |
| | Fire check door | Required | Provided | MR | |
| | Pressurization | Required | | MR | |
| | d. No. of Continuous Staircases | 05 no. | 05 nos. | IVIIN | |
| | to Terrace e. Width of Corridor | 1.50 mtr | 02 mtr | MR | |
| | f. Door Size | 01 mtr | 01 mtr | MR | |
| 03 | Compartmentation. | | | | |
| | Fire check door | Required | Provided | MR | |
| | Sealing of electrical shafts | Required | Sealed | MR | |
| | Fire rating of shaft door | 02 hrs | 02 hrs | MR | |
| | Water curtain | N/A | Provided | MR | |
| | Fire dampers | N/A | Provided | MR | |
| 04 | Smoke Management System. | | | | |
| - | Basement | 30 a/c per hour | Provided | MR | |
| | Upper floor | 12 a/c per hour | Provided | MR | |
| 05. | Fire Extinguishers. | 1111111 | | | |
| | Total numbers | 80 nos. | 130 nos. | MF | |
| | Types | ABC /CO ₂ | ABC /CO ₂ | MF | |
| | IS marking | ISI marked | ISI marked | MF | |

14/26

| 6 | First-Aid-Hose Reels. | | 04 - 0 02 nos | MR | | | |
|---------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------|--|--|--|
| R | Total numbers on each floor | 04 no. | 04 no& 02 nos extra in each | IVII. | | | |
| | - SE | | basement 30 mtr. | MR | | | |
| | Length of hose reel hose | 30 mtrs. | | MR | | | |
| | Nozzle diameter | 05 mm 05 mm | | | | | |
| 07 | NO SAFERINGERO DE LA COMPANSIONE DEL COMPANSIONE DE LA COMPANSIONE | | | | | | |
| | Type of detectors | Heat & Smoke | Ground Floor | MR | | | |
| | Location of main panel | Control Room | Provided | MR | | | |
| | Location of repeater panel | Security Room Battery & DG | Provided | MR | | | |
| | Alternate source of power | Set Set | 7 101122 | | | | |
| | Hooter's location | Different | Different | MR | | | |
| | Thousand a securior | Location | Location | | | | |
| 08 | MOEFA | Required | Provided | MR | | | |
| 09 | Public Address System. | Required | Provided | MR | | | |
| 10 | C KNAROS WILM DE A 1981 | | | | | | |
| 1 | Basement | Required | Provided | MR | | | |
| | upper floor | Required | Provided | MR | | | |
| | sprinkler above false ceiling | Required | Provided | MR | | | |
| 11 | Internal Hydrants | | | | | | |
| | size of riser/down-comer | 100 mm | 150 mm | MF | | | |
| | Number of hydrants per floor | 04 nos. | 04 no & 02 nos extra in each basement | MF | | | |
| | Hose box | 06 nos. | 06 nos. | MF | | | |
| 12 | Yard Hydrants. | | | | | | |
| | Total number of hydrants | 08 nos. | 08 nos. | MR | | | |
| 20100-1 | Hose box | 08 nos. | 08 nos. | MR | | | |
| 13 | Pumping Arrangements. | | | | | | |
| | > Ground Level | | | | | | |
| | Discharge of main pump | 2050 DM | 2950 LDM | MR | | | |
| | | 2850 LPM | 2000 LPW | IVIT | | | |
| | Head of main pump | 88 M | 2850 LPM 88 M | | | | |
| | Head of main pumpNumber of main pumps | 88 M 01 nos | | MR | | | |
| | Head of main pumpNumber of main pumpsJockey pump out put | 88 M 01 nos 180 LPM | 88 M 01 nos 180 LPM | MR | | | |
| | Head of main pump Number of main pumps Jockey pump out put Jockey pump head | 88 M 01 nos 180 LPM 88 M | 88 M 01 nos 180 LPM 88 M | MR MR MR | | | |
| | Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby pump out put | 88 M 01 nos 180 LPM 88 M 2850 LPM | 88 M 01 nos 180 LPM 88 M 2850 LPM | MR MR MR MR | | | |
| | Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby pump out put Standby pump head | 88 M 01 nos 180 LPM 88 M 2850 LPM 88 M | 88 M 01 nos 180 LPM 88 M 2850 LPM 88 M | MR MR MR MR MR | | | |
| | Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby pump out put Standby pump head Auto starting /manual stopping | 88 M 01 nos 180 LPM 88 M 2850 LPM 88 M Required | 88 M 01 nos 180 LPM 88 M 2850 LPM 88 M Provided | MR MR MR MR MR MR | | | |
| | Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby pump out put Standby pump head Auto starting /manual stopping | 88 M 01 nos 180 LPM 88 M 2850 LPM 88 M | 88 M 01 nos 180 LPM 88 M 2850 LPM 88 M | MR MR MR MR MR MR | | | |
| | Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby pump out put Standby pump head Auto starting /manual stopping Pump house access Terrace Level | 88 M 01 nos 180 LPM 88 M 2850 LPM 88 M Required Required | 88 M 01 nos 180 LPM 88 M 2850 LPM 88 M Provided Provided | MR MR MR MR MR MR MR | | | |
| | Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby pump out put Standby pump head Auto starting /manual stopping Pump house access ▼ Terrace Level | 88 M 01 nos 180 LPM 88 M 2850 LPM 88 M Required Required | 88 M 01 nos 180 LPM 88 M 2850 LPM 88 M Provided Provided | MR MR MR MR MR MR MR | | | |
| | Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby pump out put Standby pump head Auto starting /manual stopping Pump house access ▼ Terrace Level Discharge of pump Head of the pump Power supply | 88 M 01 nos 180 LPM 88 M 2850 LPM 88 M Required Required 900 lpm 40 mtr. | 88 M 01 nos 180 LPM 88 M 2850 LPM 88 M Provided Provided 900 lpm 40 mtr. | MR MR MR MR MR MR MR | | | |
| | Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby pump out put Standby pump head Auto starting /manual stopping Pump house access ▼ Terrace Level Discharge of pump Head of the pump Power supply Auto starting of pump | 88 M 01 nos 180 LPM 88 M 2850 LPM 88 M Required Required | 88 M 01 nos 180 LPM 88 M 2850 LPM 88 M Provided Provided Provided 900 lpm 40 mtr. Provided | MR MR MR MR MR MR MR MR | | | |
| | Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby pump out put Standby pump head Auto starting /manual stopping Pump house access ▼ Terrace Level Discharge of pump Head of the pump Power supply | 88 M 01 nos 180 LPM 88 M 2850 LPM 88 M Required Required 900 lpm 40 mtr. Required | 88 M 01 nos 180 LPM 88 M 2850 LPM 88 M Provided Provided 900 lpm 40 mtr. | MR MR MR MR MR MR MR MR | | | |
| | Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby pump out put Standby pump head Auto starting /manual stopping Pump house access Terrace Level Discharge of pump Head of the pump Power supply Auto starting of pump Captive Water Storage for Fire Fighting. Underground tank capacity | 88 M 01 nos 180 LPM 88 M 2850 LPM 88 M Required Required 900 lpm 40 mtr. Required Required | 88 M 01 nos 180 LPM 88 M 2850 LPM 88 M Provided Provided 900 lpm 40 mtr. Provided Provided | MR MR MR MR MR MR MR MR | | | |
| | Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby pump out put Standby pump head Auto starting /manual stopping Pump house access Terrace Level Discharge of pump Head of the pump Power supply Auto starting of pump Captive Water Storage for Fire Fighting. Underground tank capacity Draw-off connection | 88 M 01 nos 180 LPM 88 M 2850 LPM 88 M Required Required 900 lpm 40 mtr. Required Required Required | 88 M 01 nos 180 LPM 88 M 2850 LPM 88 M Provided Provided Provided 900 Ipm 40 mtr. Provided Provided | MR MR MR MR MR MR MR MR | | | |
| | Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby pump out put Standby pump head Auto starting /manual stopping Pump house access ▼ Terrace Level Discharge of pump Head of the pump Power supply Auto starting of pump Captive Water Storage for Fire Fighting. Underground tank capacity Draw-off connection Fire service inlet | 88 M 01 nos 180 LPM 88 M 2850 LPM 88 M Required Required 900 lpm 40 mtr. Required Required | 88 M 01 nos 180 LPM 88 M 2850 LPM 88 M Provided Provided Provided Provided Provided Provided 2,00,000 ltr Provided | MR MR MR MR MR MR MR MR MR | | | |
| | Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby pump out put Standby pump head Auto starting /manual stopping Pump house access Terrace Level Discharge of pump Head of the pump Power supply Auto starting of pump Captive Water Storage for Fire Fighting. Underground tank capacity Draw-off connection Fire service inlet Access to tank | 88 M 01 nos 180 LPM 88 M 2850 LPM 88 M Required Required 900 lpm 40 mtr. Required Required Required Required | 88 M 01 nos 180 LPM 88 M 2850 LPM 88 M Provided | MR MR MR MR MR MR MR MR MR MR | | | |
| | Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby pump out put Standby pump head Auto starting /manual stopping Pump house access ▼ Terrace Level Discharge of pump Head of the pump Power supply Auto starting of pump Captive Water Storage for Fire Fighting. Underground tank capacity Draw-off connection Fire service inlet | 88 M 01 nos 180 LPM 88 M 2850 LPM 88 M Required Required 900 lpm 40 mtr. Required Required Required Required Required | 88 M 01 nos 180 LPM 88 M 2850 LPM 88 M Provided Provided Provided Provided Provided Provided 2,00,000 ltr Provided | MR MR MR MR MR MR MR MR MR | | | |

| 6 | Provision of Lifts. | | 6 | |
|-------|--------------------------------------------------------------------------|----------|--------------------------------------------------------------|-----|
| | Pressurization of lift shaft Pressuri | | | |
| | Pressurization of lift lobby Communication | Required | Provided | MR |
| | Communication in lift car | N/A | N/A | N/A |
| | Firemen's area in lift car | Required | Provided | MR |
| | Firemen's grounding switch Lift signage | Required | Provided | MR |
| 17 | Standby Power Supply | Required | Provided | MR |
| 18 | Refuge Area. | Required | Provided | MR |
| 10.00 | | | | |
| | Total area | Required | 360 m², 360 m²& 170 m² | MR |
| | • Location | Required | 4 th , 6 th &7 th Floors | MR |
| 19 | Fire Control Room | | | |
| | Detector system panel | Required | Provided | MR |
| | Flow switch panel | Required | Provided | MR |
| | PA system panel | Required | Provided | MR |
| | Battery backup | Required | Provided | MR |
| | Building floor plans | Required | Provided | MR |
| 20 | Special Fire Protection systems for protection of special Risks, if Any: | N/A | N/A | N/A |

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection. The earlier shortcomings issued vide letter no. F.6/DFS/MS/Metro/2025/NDZ/969 dated 06/06/2025 has been rectified now.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rule, the FSC issued vide letter no. F6/DFS/MS/2022/NDZ/334 dated 27/07/2022 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer Name : Deepak Kumar

Designation

n : ADO (Shd)

C.F.0/

3 8 2025

Principal Director

to ol exact

29/08/20

PTO