

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/2025/WZ/ 94

Dated: 24/02/2025

**FIRE SAFETY CERTIFICATE**

Certified that the **Delhi Metro Rail corporation Ltd. at Rohini West Metro Station, Rohini, Delhi**, comprised of **Ground + Concourse + Platform** owned/ occupied by **Delhi Metro Rail corporation Ltd** has already been issued FSC by this department vide letter No. **F6/DFS/MS/2022/WZ/140 dated 31.03.2022**. The premises was re-inspected by the officer concerned of this department on **17.02.2025** in the presence of **Sh. Pushkar (Fire Inspector)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **"Assembly" Group D Sub-Division D-7** with effect from 24/02/2025 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 24/02/2025 at New Delhi by

  
**(Atul Garg)**  
**DIRECTOR**

Ph; 011-23414000

Copy to :-

1. Sh. Rajesh Aggarwal, Delhi Metro Rail corporation Ltd , Metro Bhawan, 13, Fire Brigade Lane, Barakhamba Road, New Delhi-110001.
2. Sh. Pushkar (Fire Inspector), Delhi Metro Rail corporation Ltd. at Rohini West Metro Station, Rohini, Delhi

**Conditions for the validity of fire safety certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner/ occupier shall submit a declaration **every year** in **Form 'K'** [sub rule (2) of Rule 38] provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [http://delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction (Clause 2.9.2 of UBBL-2016) or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of Rule 37] along with a copy of this Certificate, **six months** prior to its expiry."

# INSPECTION REPORT

1. Name & address of the building : Delhi Metro Rail corporation Ltd. at Rohini West Metro Station, Rohini, Delhi
2. Type of Occupancy : Assembly
3. Type of Case : Renewal (Ground + Concourse + Platform)
4. Details of Previous NOC : F6/DFS/MS/2022/WZ/ 140 dated 31.03.2022.
5. Fire Safety directives letter No : F6/MS/DFS/BP/2003/450 dated 27.02.2003 & F-4(2)/2003/Home-III/793-97 dated 29.09.2003.
6. Date of inspection : 17.02.2025
7. Name of Inspecting Officer : A. K. Sharma ADO (Rohini)
8. Name and designation of officers  
From the building side : Sh. Pushkar (Fire Inspector)
9. Year of Construction : 2004
10. Applicant's letter No. : OD No.10958 dated 03.01.2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	As per directive	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	On main road 5m -NA-	Provided On main road -NA-	MR MR -NA-
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	02nos.	02nos.	MR
	<ul style="list-style-type: none"> <li>Upper Floors</li> <li>Basements</li> </ul>	-NA-	-NA-	-NA-
	b. Width of staircases	2m	3.9m & 3.85m	MR
	<ul style="list-style-type: none"> <li>Upper Floor</li> <li>Basements</li> </ul>	-NA-	-NA-	-NA-
	c. Protection of exits	-NA-	-NA-	-NA-
	Fire check door	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Pressurization</li> </ul>	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	-NA-	-NA-	-NA-
	e. Width of Corridor	3m	Provided	MR
	f. Door Size	2m	Provided	MR
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	Required Required Required -NA- -NA-	Provided Provided Provided -NA- -NA-	MR MR MR -NA- -NA-
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	30a/c per hour 12a/c per hour	NA NA	NA NA
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	31nos. ISI marked	Provided 26ABC & 5Co2 yes	MR MR MR
6.	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	04 on each platform 30m 5mm	Provided Provided Provided	MR MR MR
7.	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> </ul>	Smoke Required Required	Provided Provided Provided	MR MR MR



	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	Required	Provided	MR
10.	<b>Automatic Sprinkler System</b>			
	• Basement	-NA-	-NA-	-NA-
	• Ground & Upper Floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	150mm	Provided	MR
	• Number of hydrants per floor	04 on each platform	Provided	MR
	• Hose Box	Required	Provided	MR
12.	<b>Yard Hydrants</b>			
	• Total number of hydrants	02nos.	Provided	MR
	• Hose Box	Required	Provided	MR
13.	<b>Pumping Arrangements</b>			
	• Ground Level			
	➤ Discharge of main Pump	1800lpm	Provided	MR
	➤ Head of Main pump	60m	Provided	MR
	➤ Number of main pumps	01nos.	Provided	MR
	➤ Jockey Pump out put	180lpm	Provided	MR
	➤ Jockey pump head	60m	Provided	MR
	➤ Standby Pump out put	1800lpm	Provided	MR
	➤ Standby Pump Head	60m	Provided	MR
	➤ Auto Starting/Manual Stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	-NA-	-NA-	-NA-
	➤ Head of the pump	-NA-	-NA-	-NA-
	➤ Power Supply	-NA-	-NA-	-NA-
	➤ Auto Starting of pump	-NA-	-NA-	-NA-
14.	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity	50,000 ltr	Provided	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	-NA-	-NA-	-NA-
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	• Pressurization of Lift lobby	-NA-	-NA-	-NA-
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17.	<b>Standby power supply</b>	Required	Provided	MR
18.	<b>Refuge Area.</b>			
	➤ Total Area	-NA-	-NA-	-NA-
	➤ Location	-NA-	-NA-	-NA-
19.	<b>Fire Control Room</b>			
	• Detector System Panel	Required	Provided	MR
	• Flow Switch Panel	-NA-	-NA-	-NA-

N/21

MR  
MR  
MR

20.	Special Fire Protection System for Protection of special Risks, if any:	Required	Provided	MR
		Required	Provided	MR
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. **F6/DFS/MS/2022/WZ/140 dated 31.03.2022** is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

*[Signature]*  
Signature of the Inspecting Officer  
Name: - Ajay Kumar Sharma  
Designation:- ADO/Rohini

DO (NW)-On leave

Dy.CFO(WZ)

DCFO/.....S.504162  
Dated.....18/2/2025

*[Signature]* 18/2/2025  
*[Signature]* 19/2/2025  
*[Signature]* 19/2/25  
*[Signature]* 19/2/25  
*[Signature]* 19/2/25

Fi letter to put up for kind perused and Signature please.

*[Signature]*  
12

*[Signature]*  
20/2/25