

c/133

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/NDZ/2025/ 252

Dated: 05/06/2025

To

Sh. Kuldeep Singh (ACP/GA-II),
Delhi Police Head Quarter,
Jai Singh Marg, New Delhi -01.

Sub: Regarding issuance of Fire Safety Certificate in r/o Delhi Police Head Quarter, Jai Singh Marg, New Delhi -01.

Sir,

This has a reference to letter no. nil dated nil & DFS diary no. 797 dated 21.04.2025, on the subject cited above. In this regard, it is to inform you that the site was jointly inspected by officers concerned of this department on dated 30.05.2025/along with Sh. Kuldeep Singh, Insp. & Mr. Vinay Kumar Saith, maintenance head, During the inspection following shortcomings were observed :-

1. Fire check door has been replaced with normal glass door at 17th floor and door closers also found removed from some fire check doors which make the pressurization ineffective.
2. Pressurization of lift lobby also found removed at 17th floor.
3. Reception is not allowed at lift lobby which makes the lobby is purposeless.
4. Detector found non functional at some places.

In view of above shortcomings, the renewal of FSC cannot be considered. Therefore, you are requested to rectify the above said shortcomings at the earliest under intimation to this department.

Yours faithfully


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

