

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE**  
**CONNAUGHT PLACE: NEW DELHI-110001**

c/80

Dated: 18 / 06 / 2025

No. F.6/DFS/MS/School/2025/SZ/ **533**

To

Ms. Priya Narayanan (Principal),  
Delhi Public School, Sector-03,  
Dwarka, New Delhi-110078

Sub: **Regarding issuance of Fire Safety Certificate in r/o Delhi Public School located at Sector-03, Dwarka Phase-1, New Delhi.**

Sir,

Please refer to your letter No. DPSDW/206/14A/Engg. dated 27.05.2025, received in this department vide outdoor diary No. 2173 dated 28/05/2025. In this connection, it is to inform you that the school premise was visited by the officers concerned of this department on 11/06/2025 in the presence Mr. Ramesh Thakur (Estate Officer) to verify the availability and operability of fire protection measures. During the inspection, the shortcomings observed are as below.

1. The continuous stairs to terrace found blocked with furniture on top floor.
2. First aid hose reel provided found non-functional.
3. Exit signage's found removed at some locations.
4. The addition/alteration plans approved by this department in 2018 has lapsed and hence, needs re-approval.

In view of the above, application for issuance of fire safety certificate is rejected. You are advised to rectify the shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

Ph. 011-23414000

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054