



C-03

75
आज़ादी का
अमृत महोत्सव

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001

No: F.6/DFS/MS/School/SZ/2026/ 70

Dated: 16/06/2026

FIRE SAFETY CERTIFICATE

Certified that the building of Delhi Public School, E-71, Vasant Vihar, New Delhi, comprised of comprised of A- Block- (Ground +02 upper floors), B Block- (basement (Sunken), G + 02 upper floors) & C- Block (Gr. + 02 upper floors) all three block are interconnected through corridor, was issued FSC vide letter No. F6/DFS/MS/GH/2022/SZ/1346 dated 14/12/2022. The premises was re inspected by the officer concerned by this department on 09/06/2026 in the presence of Sh. Naresh Kumar and observed that have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the fit for occupancy class **"Educational" Group-B** with effect from ...16/06/2026... for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to the compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Condition mentioned below.

Issued on ...16/06/2026... at New Delhi.


(A. K Malik)
Chief Fire Officer

Copy to: -

1. The Commissioner , MCD , Civic Centre , New Delhi : to kindly ensure the occupancy in basement and deviation if any.
2. The Principal, Delhi Public School, E-71, Vasant Vihar, New Delhi.
3. The Director, Director of Education, Old Secretariat, New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. Basement shall be used as per building bylaws strictly.

INSPECTION REPORT

1. Name & address of the building	Delhi Public School, E-71, Vasant Vihar, New Delhi.			
2. Type of Occupancy	Educational "Group-B" (School) 03 block , A- block (Ground + 2 upper floor) , B- block (basement(sunken) , ground and two upper floor) & C – Block(Ground + 2 upper floor) all three block are interconnected through corridor			
3. Type of Case	Renewal			
4. Details of previous NOC	F6/DFS/MS/GH/2022/SZ/1346 dated 14/12/2022			
5. Fire Safety directives letter No	Nil			
6. Date of inspection	09/06/2026			
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (BCP)			
8. Name and designation of officers from the building side	Sh. Naresh Kumar			
9. Year of Construction	1992			
10. Applicant's letter No.	On line ID - 52026032501827			

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Required	10 mtr	MR
	• Gate width	Required	4.75m, 2.6m & 2.10m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Required	03 Nos(01 at each Blk)	MR
	• Basements	02Nos	04 Nos	NA
	b. Width of staircases			
	• Upper Floors	1.25 mtr	1.35 mts each	MR(Old case)
	• Basements	1.25mtr	1.35& 0.87mX3	MR(Old case)
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	Provided	MR
	e. Width of Corridor	1.5m	Provided	MR
	f. Door Size	1 mtr	Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5	Fire Extinguishers			
	• Total numbers	44 Nos.	Provided	MR

	• Types	CO ₂ , ABC type	ABC & CO ₂	14	Capt
	• IS marking	ISI marked	Provided		
6	First-Aid Hose Reels.				
	• Total numbers on each floor	0 Nos	Provided		MR
	• Length of hose reel hose	30mtr	Provided		MR
	• Nozzle diameter	5mm	Provided		MR
7	Automatic fire detection and alarming system.				
	• Type of detectors	NA	NA		NA
	• Location of main panel	NA	NA		NA
	• Location of Repeater Panel	NA	NA		NA
	• Alternate source of power	NA	NA		NA
	• Hooters' Location	NA	NA		NA
8	MOEFA	NA	NA		NA
9	Public Address System.	NA	NA		NA
10	Automatic Sprinkler System.				
	• Basement	Required	Provided		MR
	• Upper Floor	NA	NA		NA
	• Sprinkler above false ceiling	NA	NA		NA
11	Internal Hydrants				
	• Size of riser/down-comer	NA	NA		NA
	• Number of hydrants per floor	NA	NA		NA
	• Hose Box	NA	NA		NA
12	Yard Hydrants.				
	• Total number of hydrants	NA	NA		NA
	• Hose Box	NA	NA		NA
13	Pumping Arrangements.				
	Ground Level				
	➤ Discharge of main Pump	NA	NA		NA
	➤ Head of Main pump	NA	NA		NA
	➤ Number of main pumps	NA	NA		NA
	➤ Jockey Pump out put	NA	NA		NA
	➤ Jockey pump head	NA	NA		NA
	➤ Standby Pump out put	NA	NA		NA
	➤ Standby Pump Head	NA	NA		NA
	➤ Auto Starting/ Manual stopping	NA	NA		NA
	➤ Pump House Access				
	• Terrace level				
	➤ Discharge of pump	450 LPM	450,x2 &180LPM		MR
	➤ Head of the pump	40mtr	Provided		MR
	➤ Power Supply	Required	Provided		MR
	➤ Auto Starting of pump	Required	Provided		MR

14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	15,000ltrs	15,000 ltrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift Lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	• Total Area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

Note : This file was earlier forwarded through online portal but due to technical problem in the portal, now the file is put in physical mode.

The fire protection systems provided in the building were checked randomly and found functional at the time of inspection. Further, the fire check door is not requirements as per 1st inspection note, hence, in the present inspection note same is not mentioned. The management, has submitted the undertaking dated 05.06.2026 (placed on file) that basement shall be used for storage and activity rooms, etc which is as per sanction drawing.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/GH/2022/SZ/1346 dated 14/12/2022, renewal under the rule 37 of the Delhi Fire Service rules 2010 is recommended. Accordingly, DFA is put up for approval and signatures please.

Signature of the Inspecting
~~Officer~~ 84
 Name: Sarabjeet Singh
 Designation: ADO (BCP)

Do(s/p)

15/12/24
CFR 54

14/12/24

CFR 12

14/12/24

Please ensure that the undertaking w.r.t. use of basement/occupancy shall also be communicated to the building authority with the renewed FSC.

14/12/24