

E 25

75  
आज़ादी का  
अमृत महोत्सव

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**


No.F.6/DFS/MS/School/2025/SZ/1115

Dated: 09/09/2025

**FIRE SAFETY CERTIFICATE**

Certified that the **Delhi Public School**, located at Sector-C Pocket-5, Vasant Kunj, New Delhi 110070 comprised of Block-C, Ground plus 03 Floors & Block-G, 02 Basement, Ground plus 02 Floors owner/occupied by Delhi Public School was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/20222/SZ/966 Dt. 06/09/2022. The premises was re-inspected by officer concerned of this department on 25/08/2025 in presence of Mr. Indradhanush Chowdhary (Estate) and observed that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class **"Educational Building" Group-B** with effect from 09/09/2025 for a period of Three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 09/09/2025 at New Delhi by

  
(VIRENDRA SINGH)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi 110054.
2. Delhi Public School, located at Sector-C Pocket-5, Vasant Kunj, New Delhi 110070

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The basement shall be used as per the provisions of UBBL-2016 /NBC Part- IV.
5. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

## INSPECTION REPORT

1	Name & Address of the Building	Delhi Public School, Sector-C Pocket-5, Vasant Kunj, New Delhi 110070		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Block-C, Ground plus 03 floors & Block-G, 02 Basement, Ground plus 02 floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/20222/SZ/966 Dt. 06/09/2022		
6	Fire Safety Directives Letter No	F6/DFS/MS/2018/BP/159 Dated 17/05/2018		
7	Date of Inspection	25-08-2025		
8	Name of the Inspecting Officers	ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Indradhanush Chowdhary (Estate)		
10	Year of construction	1996, 2002 & 2020		
11	Applicant letter No.	DFS Outdoor diary no 4787 dated 12/08/2025		
S. No	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>NBC/UBBL requirements</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
1	<b>Access to Building.</b>			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	Required	6 mtr	MR
		Required	4 mtr	MR
		-NA-	-NA-	-NA-
2	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	02 No's Blk G- 05	02 Nos 05 Nos	MR
	➤ Basement floor.	Blk G- 04	04 Nos	MR
	<b>b) Width of Staircase</b>			
	➤ Upper floors	1.50 & 2m Blk G-(1.50 & 4 x 2m)	1.50m, 2.17m ramp 1.50m, 4 x 2m	MR
	➤ Basement floor	2m & 1.50	Provided	MR
	<b>c) Protection of exits</b>			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	<b>d) No. of continuous staircase to terrace</b>	One each block	Provided	MR
	<b>e) Width of corridor</b>	-NA-	-NA-	-NA-
	<b>f) Door size</b>	1 mtr	1 mtr	MR
3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>Fire check door.</li> <li>Sealing of electrical shafts.</li> <li>Fire rating of shaft door.</li> <li>Water curtain</li> <li>Fire dampers.</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
4	<b>Smoke Management system.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper floors</li> </ul>	12 ACPH	Exhaust fan provided	MR
		-NA-	-NA-	-NA-
5	<b>Fire Extinguishers.</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>ISI Marking</li> </ul>	Required	25 Nos	MR
		ABC	ABC Type	MR
		ISI mark	Provided	MR
6	<b>First Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor.</li> <li>Length of hose-reel hose.</li> </ul>	02 in each blocks	Provided	MR
		30 m	Provided	MR

MB

	• Nozzle Diameter	5 mm	Provided	MR
7	<b>Automatic fire detection &amp; alarming system.</b>			
	• Type of detectors	Required	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	Required	Provided	MR
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	-NA-	-NA-	-NA-
10.	<b>Automatic Sprinkler System</b>			
	• Basement	Required	Provided	MR
	• Upper floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	<b>Internal Hydrants.</b>			
	• Size of Riser/Down-comer	Required	Provided	MR
	• Number of Hydrant per floor	Required	Provided	MR
	• Hose box.	Required	Provided	MR
12.	<b>Yard Hydrants.</b>			
	• Total number of hydrants.	Required	Provided	MR
	• Hose box.	Required	Provided	MR
13.	<b>Pumping arrangements.</b>			
	• <b>Ground Level</b>			
	➤ Discharge of main pump.	2280 LPM	Provided	MR
	➤ Head of main pump.	70m	Provided	MR
	➤ Number of main pumps.	01	Provided	MR
	➤ Jockey Pump output.	180 LPM	Provided	MR
	➤ Jockey Pump head.	70m	Provided	MR
	➤ Standby Pump output.	2280 LPM	Provided	MR
	➤ Standby Pump head.	70m	Provided	MR
	➤ Auto Starting / Manual Stopping.	Required	Provided	MR
	➤ Pump house access.	Required	Provided	MR
	• <b>Terrace Level</b>			
	➤ Discharge of pump.	900 PM for G Block 450 LPM for C	Provided	MR
	➤ Head of pump.	40 mtr	Provided	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	<b>Captive water storage for fire fighting.</b>			
	• Underground tank capacity.	1,00,000 ltrs	Provided	MR
	➤ Draw-off connection.	Required	Provided	MR
	➤ Fire Service Inlet.	Required	Provided	MR
	➤ Access to tank.	Required	Provided	MR
	• Overhead tank capacity.	20,000 ltrs for G Block & 10,000 ltrs	Provided & 10,000 ltrs	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car.	-NA-	-NA-	-NA-
	• Fireman's switch.	-NA-	-NA-	-NA-
	• Lift signage.	-NA-	-NA-	-NA-
17.	<b>Standby Power Supply</b>	Required	Provided (DG Set)	MR
18.	<b>Refuge Area</b>			

	<ul style="list-style-type: none"> <li>Total area</li> <li>Location</li> </ul>	-NA-	-NA-	-NA-
19.	<b>Fire Control Room.</b>			
	<ul style="list-style-type: none"> <li>Detector system panel.</li> <li>Flow switch panel.</li> <li>PA system panel.</li> <li>Battery backup.</li> <li>Building floor plan.</li> </ul>	-NA-	-NA-	-NA-
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	-NA-	-NA-	-NA-

The Fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/20222/SZ/966 Dt. 06/09/2022, **renewal** under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Signature of the Inspecting Officer  
 Name: Sh. Rajesh Kumar  
 Design: ADO (BCP)

DO (South)

*[Signature]*  
26/8/25

*[Signature]*  
27/8/2025

Principal Director

Cfo to Secy.

*[Signature]*  
24/08/25

*[Signature]*  
AD (BCP)

F.T. letter is put up for your signature

*[Signature]*  
8/9/2025

*[Signature]*  
8/9/2025

MS