



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आजादी का
अमृत महोत्सव

DFS/MS/School/SZ/2025/570

Dated: 01/05/2025

FIRE SAFETY CERTIFICATE

Certified that the M/s Delhi Smart School located at K-65/A, Abul Fazal Enclave, Okhla, New Delhi, running at Ground to 2nd floor of the building which is comprised of Ground + 04 upper floors (3rd Floor – Residence, 4th Floor – Sealed, affidavit regarding sealing of 4th floor has been submitted by the owner), owned Mr. Moinuddin & occupied by Delhi Smart School, has complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular bearing letter no. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01.03.2011 and verified by officer concerned of Delhi Fire Service on 25.04.2025 in the presence of Mr. Moinuddin (Chairman) and found that the Building is fit for occupancy of Group 'B' (Educational Building) with effect from 01/05/2025.. for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on 01/05/2025 at New Delhi by

(Atul Garg)
Director

Delhi Fire Service

Copy to:-

1. The Commissioner, MCD, 9th floor, Shyama Prashad Mukherjee Civic Centre : to ensure the occupancy as per the FSC.
2. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.
3. The Principal, Sita Ram Public School located at Madanpur Khadar, New Delhi-76.

Conditions for the validity of Fire Safety Certificate

1. **This Fire Safety Certificate is valid for Ground + 02 upper floors only.**
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
8. The owner / occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub Rule (1) of Rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	Delhi Smart School located at K-65/A, Abul Fazal Enclave, Okhla, New Delhi.			
2	Building is comprised of	Ground + 04 upper floors School running at Ground + 02 upper floor. 3 rd floor – Residence. 4 th floor – Sealed (affidavit submitted by the owner alongwith photographs regarding sealing of 4 th floor).			
3	Type of occupancy	Education, Group-B			
4	Type of case	Fresh			
5	Details of previous FSC	Nil			
6	Fire safety direction letter no.	DOE Circular	F.16/Estate/CC/Fire Safety/2011/3298-3398.		
7	Date of inspection	21.04.2025			
8	Name of the inspecting officers	Rajesh Kumar Shukla ADO (M. Road)			
9	Name of the designation of officer from the building side	Mr. Moinnuddin (Chairman)			
10	Year of construction/ Occupancy	2012-13			
11	Applicant's letter no.	Outdoor diary no.			
S.N	Minimum standard of fire prevention and fire safety U/R 33	Requirements as per DOE Circular 3298-3398.	Provided at site	Remarks MR/NMR	
1	Access to Building:				
	A	Road width	Accessibility	Provided	MR
	B	Gate width	NA	NA	NA
	C	Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits:				
	A	Number of staircases			
	a	Upper floor	02 nos.	2 nos.	MR
	b	Basement	NA	NA	NA
	B	Width of staircases			
	a	Upper floor	If main staircase is less than 1.5 meters an alternate staircase of 0.75 meters is required	1 mtr. and 0.95 mtr.	MR
	b	Basement	NA	NA	NA
	C	Protection of exits			
	a	Fire check door	NA	NA	NA
	b	Pressurization	NA	NA	NA
	D	No. of continuous staircases to terrace	01 no.	01 no.	MR
	E	Width of corridor	NA	NA	NA
	F	Door size	1.0 mtrs.	1.0 mtrs. (class room)	MR
3	Compartmentation:				
	A	Fire check door	NA	NA	NA
	B	Sealing of electrical shafts	NA	NA	NA
	C	Fire rating of shaft door	NA	NA	NA
	D	Water curtain	NA	NA	NA
	E	Fire dampers	NA	NA	NA
4	Smoke Management System:				
	A	Basement	NA	NA	NA
	B	Upper floor	NA	NA	NA
5.	Fire Extinguisher:				
	A	Total numbers	08 nos.	08 nos.	MR
	B	Types	CO ₂ & ABC	Provided	MR
	C	ISI marking	Required	Provided	MR

6	First-Aid-Hose Reel:			MR
	A	Total numbers of each floor	01 no.	MR
	B	Length of hose reel hose	30 m	MR
	C	Nozzle diameter	5 mm	MR
7	Automatic Fire Detection and Alarming System:			
	A	Type of detectors	NA	NA
	B	Location of main panel	NA	NA
	C	Location of repeater panel	NA	NA
	D	Alternate source of power	NA	NA
	E	Hooters	NA	NA
8	MOEFA:			NA
9	Public Address System:			NA
10	Automatic Sprinkler System:			
	A	Basement	NA	NA
	B	Upper floor	NA	NA
	C	Sprinkler above false ceiling	NA	NA
11	Internal Hydrants:			
	A	Size of riser/down-comer	NA	NA
	B	Number of hydrants per floor	NA	NA
	C	Hose box	NA	NA
12	Yard Hydrants:			
	A	Total number of hydrants	NA	NA
	B	Hose box	NA	NA
13	Pumping Arrangements:			
A	Ground level			
	a	Discharge of main pump	NA	NA
	b	Head of main pump	NA	NA
	c	Number of main pumps	NA	NA
	d	Jockey pump out put	NA	NA
	e	Jockey pump head	NA	NA
	f	Standby pump out put	NA	NA
	g	Standby pump head	NA	NA
	h	Auto starting /manual stopping	NA	NA
	i	Pump house access	NA	NA
B	Terrace Level			
	a	Discharge of pump	450 LPM	MR
	b	Head of the pump	40 mtrs	MR
	c	Power supply	Required	MR
	d	Auto starting of pump	Required	MR
14	Captive Water Storage for Fire Fighting:			
	A	Underground tank capacity	NA	NA
	B	Draw-off connection	NA	NA
	C	Fire service inlet	NA	NA
	D	Access to tank	NA	NA
	E	Overhead tank capacity	10000 ltrs	MR
15	Exit Signage:			MR
16	Provision of Lifts:			
	A	Pressurization of lift shaft	NA	NA
	B	Pressurization of lift lobby	NA	NA
	C	Communication in lift car	NA	NA
	D	Firemen's grounding switch	NA	NA
	E	Lift signage	NA	NA
17	Standby Power Supply:			NA
18	Refuge Area:			
	A	Total area	NA	NA
	B	Location	NA	NA

19	Fire Control Room:			
A	Detector system panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	PA system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plans	NA	NA	NA
20	Special Fire Protection systems for protection of special Risks, if any:	NA		NA

Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided but Not Functional (PNF), Not Provided (NP).

Note: During the inspection the School was found running from Ground to 2nd floor. The height upto 2nd floor of the building as per the elevation drawing prepared by the Registered Architect and submitted by the owner is 8.95 meters. The Owner has also submitted a copy of an Old lease agreement dated 19.12.2013, which proofs that a School was earlier running in the name of LIFT School (operated by Indian Education Foundation) in 2013 which was later taken over by the owner with a new name called Delhi Smart School. The Owner has sealed the 4th floor and submitted photographs of the same as proof.

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

If agreed to the note above, & In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required in Directorate of Education circular 3298 to 3398 dated 01.03.2011 , the FSC to the School is recommended to be issued.


25/4/25

Signature of the Inspecting Officer


Name: Rajesh Kumar Shukla


Designation ADO (M. Road)

DO (SD)


26/4/25


29/4/2025


34/4/25


34/4/25

