

c/06

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/2025/Restaurant/WZ/ 126

Dated: 20/03/2025

To,

Mr. Sunil Kumar Gupta,  
House No.A-110, 2<sup>nd</sup> floor, Paryavaran Complex,  
Mehrauli Saidulajab,  
Delhi-110042.

**Sub:** Issue of FSC in r/o M/s Delhi Spice, Shop No.95, 1<sup>st</sup> floor, Sambhu Dayal Bagh, Old Ishwar Nagar, Okhla, Delhi-110020.  
Sir,

This is in reference to your online application No. 2025020401469 dated 20.02.2025 received on the subject cited above. The premise was inspected by the concern nominated authority of this department on **11.03.2025**, in presence of **Mr. Randhir (Cashier)** to ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed:

1. Both the exits & staircases are on one side only & one staircase width is 1.1m against required width of 1.5m.
2. Fire check door is not provided in kitchen.
3. Smoke ventilation is not provided in restaurant.
4. Manually operated electric fire alarm not provided.
5. Over Head water captive tank of 10,000 ltrs provided use for both building restaurant & Delhi Haat.
6. Exit signage are not provided in restaurant.
7. Main occupancy building being Mercantile Ground + 02 upper floor falls under preview of Rule 27 of DFS Rule 2010 also required FSC from this department.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 it is advised the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

[http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

Yours faithfully

  
(Atul Garg)  
DIRECTOR  
Ph: 011-23414000

Copy to:-

1. MCD Portal ID-2025020401469 dated 20.02.2025.