



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ/ 785

Dated: 13 / 06 / 2025

FIRE SAFETY CERTIFICATE

Certified that the Building of **Deshwal Public School** located at RZ-5B, Gali No. 9, Puran Nagar, Mehrauli Road, Palam Colony, New Delhi-110045, comprised of Ground + One upper floor only, owned/occupied by Deshwal Public School, was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/SZ/School/2022/572 dated 27/05/2022. The premises was re-inspected by the officer concerned of this department on dated 03/06/2025 in the presence of Sh. Pankaj Deshwal (Manager) and found that said premises have complied with the fire prevention and fire safety requirements in accordance with DOE Circular No. 3298-3398 dated 01/03/2011 and that the premise/building is fit for occupancy class "**Educational Group B**" (School) with effect from 13 / 06 / 2025 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010.

Issued on 13 / 06 / 2025 at New Delhi by

(ATUL GARG)
 DIRECTOR
 Delhi Fire Service

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.
2. Sh. Pankaj Deshwal (Manager), Deshwal Public School at RZ-5B, Gali No. 9, Puran Nagar, Mehrauli Road, Palam Colony, New Delhi-110045

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
5. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, prior to its expiry.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

N-11

INSPECTION REPORT				
1.	Name & address of the building	Deshwal Public School located at RZ-5B, Gali No. 9, Puran Nagar Mehrauli Road, Palam Colony, New Delhi-110045		
2.	Type of Occupancy	Educational (Group-B)		
3.	Building Comprised of	Ground + One upper floors only.		
4.	Type of Case	Renewal		
5.	Details of previous NOC No.	F6/DFS/MS/SZ/School/2022/572 Dt 27/05/2022		
6.	Fire Safety directives Letter No.	DOE Circular No. 3298-3398 Dt 01/03/2011		
7.	Date of inspection	03/06/2025		
8.	Name of the Inspecting Officer	ADO (DWK)		
9.	Name and designation of Officer from the building side	Sh. Pankaj Deshwal (Owner)		
10.	Year of Construction	GF: 2004 & FF: 2010		
11.	Applicant's letter No.	Outdoor Diary No. 1666 dated 15/05/2025		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	Provided	MR
	• Gate width	4.5mtr	Directly accessible from road	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	01 Nos	02 Nos	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.5m & if less than 150m than Addl. Stair of 0.75m	1.5m & 0.90m	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	One	Provided	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	1.0 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	12 ACPH	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	02nos/Floor	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• ISI marking	ISI Marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A

7.	Automatic fire detection and alarming system	N/A	N/A	N/A
	<ul style="list-style-type: none"> Type of detector Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System			
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	N/A	N/A	N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power supply Auto starting of pump 	N/A	N/A	N/A
14.	Captive water storage for firefighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw of connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	N/A	N/A
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of lift lobby Communication in lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
17.	Standby Power Supply	N/A	N/A	N/A
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	N/A	N/A	N/A


10-13

19.	Fire Control Room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special fire protection systems for protection of special risks, if any;	Required	ABC fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were checked, tested at random and found functional at the time of inspection.


Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, the fire safety certificate issued vide letter No. F6/DFS/MS/SZ/School/2022/572 dated 27/05/2022, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.


Accordingly, DFA is put up for perusal/approval and signature please.


Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (DWK)

DO (SW)


9/6/25



9/6/2025


10/6/25



Sir, F.T. letter is pending for your sing. pl


11/6/25


11/6/25