



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/ 1259

Dated: 17/10/2025

FIRE SAFETY CERTIFICATE

Certified that the Deus Convent School located at Pocket- B1-B4, Sector-11, Rohini, Delhi- 110085 comprised of Ground & First Floor owned/ occupied by Deus Convent School was issued Fire Safety Certificated by this department vide letter No. F6/DFS/MS/2022/School/WZ/785 Dated: 26/07/2022. The premises was inspected by the officer concerned of this department on 03/10/2025 in presence of Mrs. Monalisha Sharma (Principal) and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class "Group B Educational (School)" with effect from ...17/10/2025... for a period of three years, subject to compliance of the conditions mentioned below:

Issued on17/10/2025... at New Delhi by.

(Signature)
 17/10/25

(S.K. Dua)

Dy. Chief Fire Officer
 Delhi Fire Service

(Signature)

Copy to: -

1. The Deputy Director of Education, MCD, Sector-5, Rohini Zone, Delhi - 110085.
2. The Principal, Deus Convent School located at Pocket- B1-B4, Sector-11, Rohini, Delhi- 110085.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

4/15

INSPECTION REPORT

1. Name & address of the building : Deus Convent School at Pocket- B1-B4, Sec-11, Rohini, Delhi-110085.
2. Type of Occupancy : Educational
3. Composition of building : Ground & First Floor
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/2022/School/WZ/785 Dated: 26/07/2022
6. Fire Safety directives letter No : Nil
7. Date of inspection : 03/10/2025
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers
from the building side : Mrs. Monalisha Sharma (Principal)
10. Year of Construction : 2003
11. Applicant's letter No. : Letter No. DCS/OFF/0056/Sep-25 Dated-02/09/2025

	Minimum Standards on fire prevention and fire safety U/R 33	D.O.E Circular dated 01.03.2011	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	4.56m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.14m & 1.65m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	Required	Provided	MR
	f. Door Size	01m	1.15m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilation	MR
5	Fire Extinguishers			
	• Total numbers	04nos	08nos	MR
	• Types	ABC/CO2	ABC—07/CO2-1	MR
	• ISI marking	ISI Marked	Yes	MR

9 A

6	First-Aid Hose Reels.		
	• Total numbers on each floor	NA	NA
	• Length of hose reel hose	NA	NA
	• Nozzle diameter	NA	NA
7	Automatic fire detection and alarming system.		
	• Type of detectors	NA	NA
	• Location of Main Panel	NA	NA
	• Location of Repeater Panel	NA	NA
	• Alternate source of power	NA	NA
	• Hooters' Location	NA	NA
8	MOEFA	NA	NA
9	Public Address System.	NA	NA
10	Automatic Sprinkler System.		
	• Basement	NA	NA
	• Upper Floor	NA	NA
	• Sprinkler above false ceiling	NA	NA
11	Internal Hydrants		
	• Size of riser/down-comer	NA	NA
	• Number of hydrants per floor	NA	NA
	• Hose Box	NA	NA
12	Yard Hydrants.		
	• Total number of hydrants	NA	NA
	• Hose Box	NA	NA
13	Pumping Arrangements.		
	• Ground Level		
	➤ Discharge of main Pump	N/A	N/A
	➤ Head of Main pump	N/A	N/A
	➤ Number of main pumps	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A
	➤ Jockey pump head	N/A	N/A
	➤ Standby Pump out put	N/A	N/A
	➤ Standby Pump Head	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A
	➤ Pump House Access	N/A	N/A
	• Terrace level		
	➤ Discharge of pump	N/A	N/A
	➤ Head of the pump	N/A	N/A
	➤ Power Supply	NA	NA
	➤ Auto Starting of pump	NA	NA
14	Captive Water Storage for fire fighting.		
	• Underground tank capacity	NA	NA
	➤ Draw-off connection	NA	NA
	➤ Fire service inlet	NA	NA
	➤ Access to tank	NA	NA

N/17

	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage.	N/A	N/A	N/A
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is **recommended for renewal of fire safety certificate** issued vide this department letter of even no. F6/DFS/MS/2022/School/WZ/785 Dated: 26/07/2022.

Signature of the Inspecting Officer

Name :- C.L. Meena

Designation:- ADO/R

DOANW
By CFS/COZ
DFA please.
10/10/25

King
06/10/25

Principal Director

By CFS to Sone.

By CFS (V2)

10/10/25
King
13/10/25

ADO (Rohini)

Conf. P.T.O.