



No.F6/DFS/MS/School/SZ/2025/ 118

Dated: 06/02/2025

FIRE SAFETY CERTIFICATE

Certified that the **Dev Samaj Modern School, No. 2, Okhla (Sukhdev Vihar), New Delhi-25**, comprised of Ground +02 upper floors, was granted Fire Safety Certificate (FSC) by this department vide letter no. F6/DFS/MS/School/2022/SZ/77 dated 28.01.2022. The school building was re-inspected by Assistant Divisional Officer (M. Road) from this department on 31.01.2025 in the presence of Mr. Manoj Madaan (Manager) and found that the school building has complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the premises/building (**Ground + 02 upper floors**) is fit for occupancy of Group B "**Educational Building**" (School) with effect from ...**06/02/2025**... for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on....**06/02/2025**.....at New Delhi by

(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Principal, Dev Samaj Modern School, No. 2, Okhla (Sukhdev Vihar), New Delhi-25.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	Dev Samaj Modern School, No. 2, Okhla (Sukhdev Vihar), New Delhi-25.		
2	Building is comprised of	Ground +02 upper floors		
3	Type of occupancy	Group B –Educational Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/2022/SZ/77 dated 28.01.2022		
6	Fire safety direction letter no.	DFS Act 2007 & Rules2010		
7	Date of inspection	31.01.2025		
8	Name of the inspecting officers	Rajesh Kumar Shukla, ADO (M. Road)		
9	Name of the designation of officer from the building side	Mr. Manoj Madaan (Manager)		
10	Year of construction	1975 & 2015		
11	Applicant's letter no.	Outdoor diary no. 11560 dated 20.01.2025		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement as per Rule 35 (6)	Provided at site	Remarks MR/NMR
1	Access to Building:			
A	Road width	6.0 m	6.0 m	MR
B	Gate width	4.5 mtrs	Provided	MR
C	Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits:			
A	Number of staircases			
a	Upper floor	02 nos.	3 nos.	MR
b	Basement	NA	NA	NA
B	Width of staircases			
a	Upper floor	1 staircase of 1.5 mtrs or if main staircase width is < 1.5 mtrs an additional staircase of 0.75 mtrs width is required.	1.50 m, 1.45 m & 1.35 m	MR
b	Basement	NA	NA	NA
C	Protection of exits			
a	Fire check door	NA	NA	NA
b	Pressurization	NA	NA	NA
D	No. of continuous staircases to terrace	2 nos.	3 nos.	MR
E	Width of corridor	1.5 mtrs.	1.70 m to 2.10 m	MR
F	Door size	1.0 mtrs. (for class room)	1.0 mtrs. (for class room)	MR
3	Compartmentation:			
A	Fire check door	NA	NA	NA
B	Sealing of electrical shafts	NA	NA	NA
C	Fire rating of shaft door	NA	NA	NA
D	Water curtain	NA	NA	NA
E	Fire dampers	NA	NA	NA
4	Smoke Management System:			
A	Basement	NA	NA	NA
B	Upper floor	NA	NA	NA
5.	Fire Extinguisher:			
A	Total numbers	Required	20 nos.	MR
B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
C	ISI marking	Required	Provided	MR
6	First-Aid-Hose Reel:			
A	Total numbers of each floor	03 nos.	Provided	MR
B	Length of hose reel hose	30 m	30 m	MR
C	Nozzle diameter	5 mm	5 mm	MR

7	Automatic Fire Detection and Alarming System:			
	A	Type of detectors	NA	NA
	B	Location of main panel	NA	NA
	C	Location of repeater panel	NA	NA
	D	Alternate source of power	NA	NA
	E	Hooters	NA	NA
8	MOEFA:		NA	NA
9	Public Address System:		NA	NA
10	Automatic Sprinkler System:			
	A	Basement	NA	NA
	B	Upper floor	NA	NA
	C	Sprinkler above false ceiling	NA	NA
11	Internal Hydrants:			
	A	Size of riser/down-comer	NA	100 mm
	B	Number of hydrants per floor	NA	Provided
	C	Hose box	NA	Provided
12	Yard Hydrants:			
	A	Total number of hydrants	NA	NA
	B	Hose box	NA	NA
13	Pumping Arrangements:			
A	Ground level			
	a	Discharge of main pump	NA	450 LPM
	b	Head of main pump	NA	35 m
	c	Number of main pumps	NA	NA
	d	Jockey pump out put	NA	NA
	e	Jockey pump head	NA	NA
	F	Standby pump out put	NA	NA
	f	Standby pump head	NA	NA
	g	Auto starting /manual stopping	NA	Provided
	h	Pump house access	NA	NA
B	Terrace Level			
	a	Discharge of pump	450 LPM	450 LPM
	b	Head of the pump	40 m	40 m
	c	Power supply	Required	Provided
	d	Auto starting of pump	Required	Provided
14	Captive Water Storage for Fire Fighting:			
	A	Underground tank capacity	NA	10,000 ltrs
	B	Draw-off connection	NA	NA
	C	Fire service inlet	NA	NA
	D	Access to tank	NA	NA
	E	Overhead tank capacity	10,000 ltrs	Provided
15	Exit Signage:		Required	Provided
16	Provision of Lifts:			
	A	Pressurization of lift shaft	NA	NA
	B	Pressurization of lift lobby	NA	NA
	C	Communication in lift car	NA	NA
	D	Firemen's grounding switch	NA	NA
	E	Lift signage	NA	NA
17	Standby Power Supply:		NA	NA
18	Refuge Area:			
	A	Total area	NA	NA
	B	Location	NA	NA

2/17


Dev Samaj Modern School, No. 2, Okhla (Sukhdev Vihar), New Delhi-25.

19	Fire Control Room:			
	A Detector system panel	NA	NA	NA
	B Flow switch panel	NA	NA	NA
	C PA system panel	NA	NA	NA
	D Battery backup	NA	NA	NA
	E Building floor plans	NA	NA	NA
20	Special Fire Protection systems for protection of special Risks, if any:	NA		NA

LEGENDS: Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided but Not Functional (PNF), Not Provided (NP).


The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rule, the FSC issued vide letter no. F6/DFS/MS/School/2022/SZ/77 dated 28.01.2022 is recommended to be renewed.


 31.1.25.
 Signature of the Inspecting Officer
 Name Rajesh Kumar Shukla
 Designation ADO (M. Road)

DO (SD)

COP (RCS)


 4/21/2025

Director


 1/9/25

