



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/2025/WZ/EH/ 278
To,

Dated: 19/06/2025

Mr. Abhishek Mittal,
House No.A-43, Ground floor,
Sarita Vihar,
New Delhi-110076.

Sub: Renewal of FSC in r/o Pizza Hut a Unit of M/s Devyani International Ltd. Unit no.1, Gr. floor,
Plot No.6, Garg Trade Centre, Sector-11, Rohini, Delhi-85.

Sir,

This is refer to online application no. 2025052009737 dated 20.05.2025, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **10.06.2025**, in presence of **Mr. Vinod (Store Manager)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Smoke exhaust system not provided in restaurant.
2. Hose reel found removed near to restaurant.
3. Public Address System found removed.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" /MCD Portal with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully

(Atul Garg)
DIRECTOR

Ph; 011-23414000

o/c

Copy To:-

1. MCD Portal Id- 2025052009737 dated 20.05.2025.