



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/EH/NDZ/2025/ 305

Dated: 08 / 07 / 2025

To,

The Joint Commissioner of Police (Lic),
First floor Police Station Defence Colony,
New Delhi - 110024.

Subject: - Regarding Grant of Fire Safety Certificate in r/o Pizza Hut (a unit of M/s Devyani International Ltd.), Unit no.1, Gr. Floor, Plot No.6, Garg Trade Centre, Sector-11, Rohini, Delhi-85.

Sir,

Please refer to your MCD Portal application No. 2025062310425 dated 24/06/2025 on the subject cited above. In this connection, it is to inform you that the site was visited by officer concerned of this department on 30/06/2025 in the presence of Ms. Pooja (Manager) and observed that the shortcoming are still not complied with as issued by this department vide letter no. F6/DFS/MS/2025/WZ/EH/278 dated 19/06/2025 (copy overleaf).

In view of above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier.

Yours faithfully,

Enclosed: As above

ATUL GARG
DIRECTOR
DELHI FIRE SERVICE
3/7

Copy to: -

1. The Manager, Pizza Hut (a unit of M/s Devyani International Ltd.), Unit no.1, Gr. Floor, Plot No.6, Garg Trade Centre, Sector-11, Rohini, Delhi-85.



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/2025/WZ/EH/ 278
To,

Dated: 19/06/2025

Mr. Abhishek Mittal,
House No.A-43, Ground floor,
Sarita Vihar,
New Delhi-110076.

Sub: Renewal of FSC in r/o Pizza Hut a Unit of M/s Devyani International Ltd. Unit no.1, Gr. floor,
Plot No.6, Garg Trade Centre, Sector-11, Rohini, Delhi-85.

Sir,

This is refer to online application no. 2025052009737 dated 20.05.2025, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 10.06.2025, in presence of Mr. Vinod (Store Manager) to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Smoke exhaust system not provided in restaurant.
2. Hose reel found removed near to restaurant.
3. Public Address System found removed.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" /MCD Portal with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully


(Atul Garg)
DIRECTOR
Ph: 011-23414000
o/c

Copy To:-

1. MCD Portal Id- 2025052009737 dated 20.05.2025.