



C/71

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No.F6/DFS/MS/Hospital/2025/NDZ/ 76

Dated: 15/01/2025

To,

Dr. Vandana Bagga, DGHS (Link Officer)
DGHS Building,
F-17, Karkardooma,
Delhi

Subject:-Regarding issuance of Fire Safety Certificate in r/o DGHS Building at F-17, Karkardooma, Delhi.

Sir,

With reference your letter No. F.N/9/125/DHS/CT/13-14-/1203 dated 10/10/2024 on the subject cited above. In this regard, it is to inform you that, the inspection of the above said premises was carried out by the team of officer of this department in presence Dr. Poonam (CMO) on dated 06/01/2025. During the inspection it was observed that the shortcomings as communicated earlier vide letter No. F.6/DFS/MS/2021/NDZ/1318 dated 06/07/2021 have not been complied as yet (The copy of the same is enclosed for reference).

In view of the above Fire Safety Certificate cannot be considered at this stage. You are once again requested to rectify the said shortcoming under intimation to this office for further consideration in the matter.

Encl:- As above

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Executive Engineer (E),
HMED (East), GTB Hospital Complex, Shahdara, Delhi

o/c
R.

10

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/2021/NDZ/ 1318

Dated: 06 /07/2021

To,

The Assistant Engineer (HE)-3,
HMED (East), PWD, GTB Hospital,
Shahdara, Delhi-110095

Subject: Inspection of Fire Alarm & Fire Fighting system at Directorate Health Service Building, F-17, Director General of Health Services, Karkardooma, Delhi.


Sir,

With reference to letter no. 23(Misc)/A.E.(E)/H.E-3/PWD/GTBH/2021/100 dated 03/04/2021 on the subject cited above, it is informed that officers concerned of this department inspected the premises from fire safety point of view in presence of Mr. Rajan Pathak, JE (Elec) PWD on dated 02/07/2021. The building comprises of basement, ground plus seven upper floors. During the course of inspection following observation were made:-

1. The firefighting system, detection system, Manually Operated Electric Fire Alarm system and PA system which has been provided in the building was not functional at the time of inspection.
2. Fire/Smoke check doors, hoses & hose reels in FHCs are required to be provided as per guidelines issued vide letter no. F.6/DFS/MS/97/908 dated 29/07/1997 and Vide letter no. F.6/DFS/MS/2002/944 dated 13/06/2002.
3. Lift should be provided with fireman switch and communication system as per guidelines.
4. Loose wiring was observed at various floors at the time of inspection. The same should be in conduit as per guidelines.
5. The fire shaft shall be free from electrical wires as indicated to inspection team from building side.
6. Exits, lifts, AC plant, battery room, FHCs etc found locked and blocked by stores, papers, hand sanitizers, almirah etc. same should be removed with immediate effect.
7. Offices and temporary structures erected in Means of Escape should be removed at once.
8. No LPG/Canteen is allowed at upper floors.
9. In view of the hazards and present scenario Automatic sprinkler System should be extended to all floors and false ceiling wherever applicable.
10. Exit signage are required to be provided in the premises at all exits.

This department, vide its letter no. F.6/DFS/MS/2019/4230 dated 15/07/2019 had suspended any occupancy of the building until FSC is issued. In view of the above, the building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to rectify the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours Faithfully,


(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Ph. 011- 23412025

Copy to:-

1. State Drug Authority, F-17, Karkardooma, Delhi
2. DGHS, F-17, Karkardooma, Delhi