

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No. F6/DFS/MS/EH/SZ/2026/496

Dated: 12/05/2026

To,

The Commissioner MCD,
Civic Centre, Minto Road,
New Delhi- 110002.

Sub: Regarding renewal of FSC from fire safety point of view in r/o. M/s. Dhaba by Sona, Located at G1, G2 & G3 Oblique 70, Ground Floor, Great Eastern Centre, Nehru Place, New Delhi- 110019.

Sir,

Please refer to your online application no. No. 2026042305646 dated-27/04/2026, on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 07/05/2026 in the presence of Sh. Babu Ram (Manager) to see the functioning of fire safety Equipments provided in the building.

During inspection, the following shortcomings were observed.

1. First Aid Hose reel is provided but it is not functional.
2. MOEFA is provided but not functional.
3. Overhead tank capacity of 10,000ltrs provided against the requirement of 20,000ltrs.

In view of above Shortcomings, the application for renewal of Fire safety Certificate is cannot considered at this stage & rejected. The occupancy of the building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier.

Yours faithfully,


(A.K. Malik)

Chief Fire Officer

01/05/26

Copy To: -

1. The Owner/occupier, M/s. Dhaba by Sona, Located at G1, G2 & G3 Oblique 70, Ground Floor, Great Eastern Centre, Nehru Place, New Delhi-110019. (Online application No. 2026042305646 dated-27/04/2026).