

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F.6/DFS/MS/EH/2025/SZ/ 368

Dated: 29/09/2025

To

The Commissioner,
Municipal Corporation of Delhi,
E-1, 9th Floor, Dr. SPM Civic Centre,
Minto Road, New Delhi-110002

Subject: Regarding issuance of Fire Safety Certificate in r/o **M/s Dhaba Estd. 1986 Delhi** (Rampushp Hospitality LLP) at 21/31, Block L, Mall Road Delhi, Civil Lines, Delhi -110054

Sir,

This has reference with **MCD Portal 2025080512250 dated 13/08/2025** on the subject cited above. In this connection, it is to inform you that premise was inspected by the officer concerned of this department on 25/08/2025 in the presence of Mr. Ram Prashad (Captain) to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations: -

1. There are two exits available in the restaurant having width of main exit 2m & alternative exit 1m. The alternative exit width is having width of 1.50m and also available through kitchen area, which is not acceptable as per rule.
2. First Aid Hose Reel found non-functional.
3. MOEFA found not functional.
4. Internal hydrant found non-functional.
5. Fire fighting pumps capacity 450 LPM found non- functional.
6. Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate **is rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


81/9/2025
(VIRENDRA SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

