



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

C-34



No: F.6/DFS/MS/2025/WZ/ 852

Dated: 27/11/2025

To,

The Principal,
Dhaka Public School,
F-169, Adhyapak Nagar,
Nangloi, New Delhi-110041.

Sub:- Renewal of Fire Safety Certificate in respect of Dhaka Public School located at F-169, Adhyapak Nagar, Nangloi, New Delhi- 110041.

Sir,

This has reference to your e mail id dated 04/11/2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 15.11.2025 to check the compliance of shortcomings issued vide letter no. F6/DFS/MS/School/2020/58 dated 27/01/2020. Mr. Abhishek Dhaka was present at the time of inspection.

During the course of inspection it was observed that the school building is comprised of Ground and First floor. Your request for renewal of FSC is rejected as the following shortcomings were observed:-

1. First aid hose reels found provided but not functional.
2. MOEFA found provided but not functional.
3. Terrace level pump found provided but not functional.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully

(Signature)
27/11/25

(S.K. Dua)

Dy. Chief Fire Officer
West Zone

(Signature)

Copy to :-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.