



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आजादी का
अमृत महोत्सव

No. F6/DFS/MS/School/WZ/2025/213

Dated:- 06/03/2025

FIRE SAFETY CERTIFICATE

Certified that the Dharam Deep Sec. Public School (ID-1617141) Located at J-Block, Adhyapak Nagar, Near Narayan Dharam Kanta, Najafgarh Road, Nangloi, Delhi-110041, comprised of Ground + 03 Upper Floors only, was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/School/WZ/2022/415 dated 13/04/2022. The said premise was re-inspected by the officer concerned of this department on 21/02/2025 in the presence of Sh. Sonu (Supervisor) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with NBC (Part-IV) and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 06/03/2025 for a period of **three years**, in accordance with Rule 36 unless renewal under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the DFS Rules, 2010, printed below.

Issued on 06/03/2025 at New Delhi by.

(Atul Garg)
Director

Tel. No. 011-23414000

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.
2. The Principal, Dharam Deep Sec. Public School (ID-1617141), J-Block, Adhyapak Nagar, Near Narayan Dharam Kanta, Najafgarh Road, Nangloi, Delhi-110041.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name and address of the building: **Dharam Deep Sec. Public School** located at **J-Block, Adhyapak Nagar, Near Narayan Dharam Kanta, Najafgarh Road, Nangloi, Delhi**
2. Type of Occupancy : Educational, (G+03 Upper Floors only)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/WZ/2022/415 dated 13/04/2022
5. Fire Safety directives Letter No. : NBC (Part-IV)
6. Date of inspection : 21/02/2024
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer
from the building side : Sh. Sonu (Supervisor)
9. Year of Construction : 2009
10. Applicant's letter No. : DDSPS/2025/957 dated 13/01/2025

| S No | Minimum standards on fire prevention and fire safety U/R 33 | As per Clause 35 (VI) of DFS Rules-2010 | Provided at site | Remarks MR/NMR |
|------|---|---|---------------------------|-------------------|
| 1. | Access of building | | | |
| | • Road width | 06 m | Provided | MR |
| | • Gate width | 4.5 m | Provided | MR |
| | • Width of internal road | NA | NA | NA |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | • Upper floors | 02 | 03 | MR |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | • Upper floors | 1.5 m | 1.20 m x 02 & 0.95 m x 01 | MR being old case |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | d. No of continuous staircase to terrace | 02 | Provided | MR |
| | e. Width Of Corridor | 1.5 m | 4.0 m | MR |
| | f. Door Size | 1.0 m | Provided | MR |
| 3. | Compartmentation | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4. | Smoke managements System | | | |
| | • Basements | NA | NA | NA |
| | • Upper floors | NA | NA | NA |

| | | | | |
|-----|--|-----------------------|-------------|----|
| 5. | Fire Extinguishers | | | |
| | • Total numbers | 06 nos. | 08 nos. | MR |
| | • Types | ABC & CO ₂ | Provided | MR |
| | • IS marking | ISI marked | Provided | MR |
| 6. | First – Aid Hose Reels | | | |
| | • Total numbers on each floor | 02 | Provided | MR |
| | • Length of hose reel hose | 30 m | Provided | MR |
| | • Nozzle diameter | 5 mm | Provided | MR |
| 7. | Automatic fire detection and alarming system | | | |
| | • Type of detectors | NA | NA | NA |
| | • Location of Main Panel | NA | NA | NA |
| | • Location of Repeater Panel | NA | NA | NA |
| | • Alternate source of power | NA | NA | NA |
| | • Hooters' Location | NA | NA | NA |
| 8. | MOEFA | NA | NA | NA |
| 9. | Public Address System | NA | NA | NA |
| 10. | Automatic Sprinkler System | | | |
| | • Basements | NA | NA | NA |
| | • Upper Floor | NA | NA | NA |
| | • Sprinkler above false ceiling | NA | NA | NA |
| 11. | Internal Hydrants: | | | |
| | • Size of riser/down- comer | 100 mm | Provided | MR |
| | • Number of hydrants per floor | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 12. | Yard Hydrants | | | |
| | • Total number of hydrants | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 13. | Pumping Arrangements: | | | |
| | • Ground Level | | | |
| | • Discharge of main pump | NA | NA | NA |
| | ➤ Head of main pump | NA | NA | NA |
| | ➤ Number of main pumps | NA | NA | NA |
| | ➤ Jockey pump out put | NA | NA | NA |
| | ➤ Jockey pump head | NA | NA | NA |
| | ➤ Standby Pump out put | NA | NA | NA |
| | ➤ Standby Pump Head | NA | NA | NA |
| | ➤ Auto Staring/Manual stopping | NA | NA | NA |
| | ➤ Pump House Access | NA | NA | NA |
| | • Terrace level | | | |
| | ➤ Discharge of pump | 450 lpm | 450 lpm x 2 | MR |
| | ➤ Head of the pump | 40 m | Provided | MR |
| | ➤ Power supply | Required | Provided | MR |
| | ➤ Auto starting of pump | Required | Provided | MR |
| 14. | Captive water Storage for fire fighting: | | | |
| | • Under ground tank capacity | NA | NA | NA |
| | ➤ Draw off connection | NA | NA | NA |
| | ➤ Fire service inlet | NA | NA | NA |
| | ➤ Access to tank | NA | NA | NA |
| | • Overhead Tank capacity | 10,000 ltrs. | Provided | MR |
| 15. | Exit Signage | Required | Provided | MR |
| 16. | Provision of Lifts | | | |
| | ➤ Pressurization of Lift Shaft | NA | NA | NA |
| | ➤ Pressurization of lift lobby | NA | NA | NA |
| | ➤ Communication in lift Car | NA | NA | NA |
| | ➤ Fireman's Grounding Switch | NA | NA | NA |
| | ➤ Lift Signage | NA | NA | NA |
| 17. | Standby power supply | NA | NA | NA |

| | | | | |
|-----|--|----|----|----|
| 18. | Refuge Area | | | |
| | ➤ Total area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |
| 19. | Fire control room | | | |
| | ➤ Detector system panel | NA | NA | NA |
| | ➤ Flow Switch Panel | NA | NA | NA |
| | ➤ PA System Panel | NA | NA | NA |
| | ➤ Battery backup | NA | NA | NA |
| | ➤ Building Floor Plans | NA | NA | NA |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | NA | NA | NA |

Fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no. F6/DFS/MS/School/WZ/2022/415 dated 13/04/2022 renewal under rule 35 of the Delhi Fire Service Rule 2010, is recommended.

Accordingly, DFA is prepared & put up for approval please.

[Signature]
24/02/25
Aman Kumar Lathar
ADO (JWP)

[Signature]
24/02/25

[Signature]
27/2

[Signature]
27/02/25

[Signature]
28/02/25

[Signature]
28/02/25
28/02/25
28/02/25

Sir, F.S. letter is put-up for signature pl.

[Signature]
28/02/25
m

[Signature]
28/02/25
ADO (JWP)