

c/32



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/ 809

Dated: 13 / 11 / 2025

To

The Manager
Dhruv Public School
Z-134, Prem Nagar, Kirari,
Nangloi, Delhi-110086.

Sub: - Regarding renewal of fire safety certificate in r/o Dhruv Public School located at Z-134, Prem Nagar, Kirari, Nangloi, Delhi-110086.

Sir,

Please refer to your letter received through online e-mail dated 25/09/2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 31/10/2025 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of ground & 02 upper floors only. At the time of inspection Sh. Subhash Malik (Manager) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. Fire extinguishers are provided but not functional.
2. Hose reel hose is provided but not functional and in damaged condition, some nozzles found missing.
3. Terrace level fire pump capacity of 450 LPM is provided but non functional.
4. Terrace level fire water tank capacity of 4,000 LTR is provided against the requirement of 10,000 LTR.
5. Exit & floors signage's found removed at strategic location in the school building.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school premises is at your own risk & responsibility.

Yours faithfully



(S.K. Dua)

Dy. Chief Fire Officer

Delhi Fire Service



Copy to:-

1. The Dy. Director of Education, Zone- XIII, District North West- B (II), Sector-9, Rohini, Delhi - 110085.