

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/School/2025/NDZ/ 488

Dated: 15/04/2025

FIRE SAFETY CERTIFICATE

Certified that the Dhruv Public School located at E-27, Gali No.03 Bhagirathi Vihar, Ph-1, Delhi-110094, school building comprised of Ground plus one upper floor only owned / occupied by Dhruv Public School, has already been issued Fire Safety Certificate Vide letter No. F6/DFS/MS/School/2018/NDZ/127 dated 22/01/2018. The premises was re-inspected by the officer concerned of this department on 04/04/2025 in the presence of Sh. Keshav Singh (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Circular No. F16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and found that the school building is fit for occupancy class "Educational" (Group-B) with effect from 15/04/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010. Subject to conditions printed below.

Issued on 15/04/2025 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to :-

1. The Manager, Dhruv Public School located at E-27, Gali No.03 Bhagirathi Vihar, Ph-1, Delhi-110094.
2. The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-110053.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in.

INSPECTION REPORT

N/12

1. Name & address of the building: Dhruv Public School, E-27, Gali No.3,
Bhagirathi Vihar, Ph-1, Delhi-110094.
2. Type of Occupancy : Educational, Group-B(School)
3. Building Comprised of : Ground plus one upper floor only
4. Type of Case : Renewal
5. Details of previous FSC No. F6/DFS/MS/School/2018/NDZ/127 dated 22/01/2018
6. Fire Safety directives Letter No. : DOE Cir. 3298-3398 Dated 01/03/2011
7. Date of inspection : 04/04/2025
8. Name of the Inspecting Officer : A.K. Jaiswal (D.O.)
9. Name and designation of Officer
from the building side : Sh. Keshav Singh (Manager)
10. Year of Construction : 2006
11. Applicant's letter no received : Outdoor Diary No. 12535 dt. 17/02/2025

| S No | Minimum standards on fire prevention and fire safety U/R 33 | DOE Cir. 2011 requirement | Provided at site | Remarks MR/NMR |
|------|---|---------------------------|------------------|----------------|
| 1. | Access of building | | | |
| | • Road width | 6m | 6m | MR |
| | • Gate width | NA | NA | NA |
| | • Width of internal road | NA | NA | NA |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | • Upper floors | 1 | 2 | MR |
| | • Basements | NA | NA | NA |
| | Width of staircases | | | |
| | • Upper floors | 1.50 mtr | 0.90 & 0.85 m | MR |
| | • Basements | NA | NA | NA |
| | Protection of exits | | | |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | b. No of continuous staircase to terrace | 1 | 2 | MR |
| | c. Width Of Corridor | 1.50 m | 1.50 m ✓ | MR |
| | d. Door Size | 1.00m | 1.00m ✓ | MR |
| 3. | Compartmentation | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4. | Smoke managements System | | | |
| | • Basements | NA | NA | NA |
| | • Upper floors | NA | NA | NA |
| 5. | Fire Extinguishers | | | |
| | • Total numbers | 4 Nos | 5 Nos ✓ | MR |
| | • Types | ABC /Co ₂ | Provided | MR |
| | • ISI marking | ISI Marked | Provided | MR |

A

ind
d

| | | | | |
|-----|--|----|----|----|
| 6. | First – Aid Hose Reels | | | |
| | • Total numbers on each floor | NA | NA | NA |
| | • Length of hose reel hose | NA | NA | NA |
| | • Nozzle diameter | NA | NA | NA |
| 7. | Automatic fire detection and alarming system | | | |
| | • Type of detector | NA | NA | NA |
| | • Location of Main Panel | NA | NA | NA |
| | • Location of Repeater Panel | NA | NA | NA |
| | • Alternate source of power | NA | NA | NA |
| | • Hooters' Location | NA | NA | NA |
| 8. | MOEFA | NA | NA | NA |
| 9. | Public Address System | NA | NA | NA |
| 10. | Automatic Sprinkler System | | | |
| | • Basements | NA | NA | NA |
| | • Upper Floor | NA | NA | NA |
| | • Sprinkler above false ceiling | NA | NA | NA |
| 11. | Internal Hydrants | | | |
| | • Size of riser/down- comer | NA | NA | NA |
| | • Number of hydrants per floor | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 12. | Yard Hydrants | | | |
| | • Total number of hydrants | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 13. | Pumping Arrangements | | | |
| | • Ground Level | | | |
| | • Discharge of main pump | NA | NA | NA |
| | ➤ Head of main pump | NA | NA | NA |
| | ➤ Number of main pumps | NA | NA | NA |
| | ➤ Jockey pump out put | NA | NA | NA |
| | ➤ Jockey pump head | NA | NA | NA |
| | ➤ Standby Pump out put | NA | NA | NA |
| | ➤ Standby Pump Head | NA | NA | NA |
| | ➤ Auto Staring/Manual stopping | NA | NA | NA |
| | ➤ Pump House Access | NA | NA | NA |
| | • Terrace level | | | |
| | ➤ Discharge of pump | NA | NA | NA |
| | ➤ Head of the pump | NA | NA | NA |
| | ➤ Power supply | NA | NA | NA |
| | ➤ Auto starting of pump | NA | NA | NA |
| 14. | Captive water Storage for fire fighting | | | |
| | • Underground tank capacity | NA | NA | NA |
| | ➤ Draw of connection | NA | NA | NA |
| | ➤ Fire service inlet | NA | NA | NA |
| | ➤ Access to tank | NA | NA | NA |
| | • Overhead Tank capacity | NA | NA | NA |

| | | | | |
|-----|--|----|----|----|
| 15. | Exit Signage | NA | NA | NA |
| 16. | Provision of Lifts | | | |
| | ➤ Pressurization of Lift Shaft | NA | NA | NA |
| | ➤ Pressurization of lift lobby | NA | NA | NA |
| | ➤ Communication in lift Car | NA | NA | NA |
| | ➤ Fireman's Grounding Switch | NA | NA | NA |
| | ➤ Lift Signage | NA | NA | NA |
| 17. | Standby power supply | NA | NA | NA |
| 18. | Refuge Area | | | |
| | ➤ Total area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |
| 19. | Fire control room | | | |
| | ➤ Detector system panel | NA | NA | NA |
| | ➤ Flow Switch Panel | NA | NA | NA |
| | ➤ PA System Panel | NA | NA | NA |
| | ➤ Battery backup | NA | NA | NA |
| | ➤ Building Floor Plans | NA | NA | NA |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | NA | NA | NA |

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/School/2018/NDZ/127 dated 22/01/2018 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : D.O. (East)

By: C.F.O./NDZ
div
07/04/25

C.F.O.
8/4/2025

Director
Sir, As Approved, F.T. is added. Pl.
Director
8/4/25

Ak Jaiswal
04/04/2025

8/4/2025