



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव
128

No. F6/DFS/MS/Hospital/NDZ/2025/ 455

Dated: 15/09/2025

To,

The Medical Superintendent,
Diabetic Endocrine and Metabolic Care Centre,
G.T.B Hospital Complex, Shahdara Delhi-95.

Subject: - Regarding grant of Fire Safety Certificate in r/o Diabetic Endocrine and Metabolic Care Centre at G.T.B Hospital Complex, Shahdara Delhi-95.

Sir,


This has a reference to letter no. 54(1)/A.E(E)/HE-1/HMESD/GTBH/2025/23 dated 20/03/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 03/09/2025 in the presence of Mr. Jagbir Singh, A.E(E) and observed that building comprised of Basement + Ground + 04 upper floors.

Following shortcomings were observed during time of inspection:

1. Hose reel hose nozzle found removed at some places.
2. MOEFA provided but found not functional.
3. Internal hydrant found not functional.
4. Fire pump not on auto mode.
5. Basement found encroached with waste material that should be removed for the free movement of General public in case of emergency.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


14/9/2025
VIRENDRA SINGH
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to:-

1. The Medical Superintendent, Nursing Homes, Directorate General of Health Services, Govt. of NCT of Delhi, 3rd floor, Delhi Govt. Dispensary Building, S-1, School Block, Shakarpur, Delhi - 110032.
2. The Executive Engineer (E), HMED(East), PWD, GTB Hospital complex, Shahdara, Delhi-110095.