



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Hospital/2024/SZ/ 210

Dated: 06 / 05 / 2025

To

Sh. Satesh Kumar,
 ASO (Fire Safety),
 Administrative Block,
 AIIMS, New Delhi-110029

Sub: **Renewal of Fire Safety Certificate in r/o Dinning Block, AIIMS Complex, Ansari Nagar, New Delhi-110029**

Sir,

This is with reference to the email received from Id: satesh@aiims.gov.in dated 05/03/2025, on the subject cited above. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department on dated 26/04/2025 to see the performance of fire protection measure in the presence of Sh. Harinder Singh (Dy. CSO). During the inspection, the shortcomings observed are as below.

1. Electrical shaft found unsealed vertically & horizontally at some levels.
2. Smoke exhaust system in basement found non-functional.
3. First Aid hose-reel found non-functional.
4. Automatic fire detection system found non-functional at some places.
5. Manually operated electrical call points found non-functional.
6. Automatic sprinkler system needs to be extended in left out area in basement.
7. Hose boxes near internal and external hydrants found without hoses & branch.
8. Lift was under installation.

In view of the above, the application for renewal of Fire Safety Certificate is rejected. You are advised to rectify the shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

(ATUL GARG)
 DIRECTOR
 Ph. 011-23414000

Copy to: -

1. The Director, All India Institute of Medical Science, Ansari Nagar, New Delhi-110029