



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

7/5  
आज़ादी का  
अमृत महोत्सव

No. F6/DFS/MS/Hospital/NDZ/2025/ 85

Dated 03/03/2025

To,

Mr. Ashok Kumar Sharma (Chief Architect)  
CPWD, Room No. 307  
"A" Wing Nirman Bhawan,  
New Delhi.

**Subject: - Regarding grant of Fire Safety Certificate in r/o Dispensary Cum Diagnostic Center for E.S.I.C, located at Mayur Vihar, Phase – I, Delhi - 110092.**

Sir,

This has a reference to your outdoor diary no. 4712 dated 30/07/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 17/02/2025 in the presence of Mr. Ashok Kumar Sharma (Chief Architect) and observed that building comprised of basement, stilt + ground plus three upper floors.

**Following shortcomings were observed during time of inspection:**

1. Smoke management system provided in basement but not functional.
2. First-Aid-Hose Reel provided but found defective not functional.
3. Automatic Fire Detection and Alarming System provided but not functional.
4. MOEFA provided but not functional.
5. Automatic Sprinkler System provided but found not functional.
6. Yard Hydrants provided but not functional.
7. Fire Pumps are not on auto mode.
8. Exit & floors Signage's not provided at strategic location in the building.
9. Pressurization of lift shaft and lift lobby stair case & corridors provided but not functional.
10. Lift signage's not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

01/03/2025  
DELHI FIRE SERVICE

**Copy to: -**

1. The Medical Superintendent, Nursing Homes, Directorate General of Health Services, Govt. of NCT of Delhi, 3<sup>rd</sup> floor, Delhi Govt. Dispensary Building, S-1, School Block, Shakarpur, Delhi – 110032.