



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/ 479

Dated: 15/04/2025

FIRE SAFETY CERTIFICATE

Certified that the Divine Mother Public School located at 140/8, B-block, Sant Nagar, Behind Bangali Colony Burari Road, Delhi-110084 comprised of Ground & First Floor owned/occupied by Divine Mother Public School was issued Fire Safety Certificated by this department vide letter F6/DFS/MS/2022/School/WZ/333 dated 29.03.2022. The premises was inspected by the officer concerned of this department on 29.03.2025 in presence of Sh. Amit Puri (Teacher) and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class "Group B Educational (School)" with effect from ..15/04/2025... for a period of three years, subject to compliance of the conditions mentioned below:

Issued on ...15/04/2025... at New Delhi by.

(Atul Garg)
Director
Ph:-011-23414000

Copy to: -

1. The Deputy Director of Education, GNCT of Delhi, Zone-VII, District North Lucknow Road, Timarpur, Delhi – 110054.
2. The Principal, Divine Mother Public School located at 140/8, B-block, Sant Nagar, Behind Bangali Colony Burari Road, Delhi-110084.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Divine Mother Public School at 140/8, B-block, Sant Nagar, Burari, Delhi-84.
2. Type of Occupancy : Educational
3. Composition of building : Ground & First floor only
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/2022/School/WZ/333 dated 29.03.2022
6. Fire Safety directives letter No : Nil
7. Date of inspection : 29.03.2025
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers
from the building side : Mr. Amit Puri (Teacher)
9. Year of Construction : 2008
10. Applicant's letter No. : Online E-Mail I.D dated: 24.03.2025

| | Minimum Standards on fire prevention and fire safety U/R 33 | D.O.E Circular dated 01.03.2011 Requirements | Provided at site | Remarks MR/NMR |
|---|---|--|----------------------|----------------|
| 1 | Access to building | | | |
| | <ul style="list-style-type: none"> Road width Gate width Width of internal road | Accessible | Accessible | MR |
| | | Directly Accessible | Directly Accessible | MR |
| | | NA | NA | NA |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | <ul style="list-style-type: none"> Upper Floors Basements | 02 | 02 | MR |
| | | NA | NA | NA |
| | b. Width of staircases | | | |
| | <ul style="list-style-type: none"> Upper Floors Basements | 1.50m or less and 75cm | 1.50m (Iron) & 1.30m | MR |
| | | NA | NA | NA |
| | c. Protection of exits | | | |
| | <ul style="list-style-type: none"> Fire check door Pressurization | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | d. No. of continuous staircases to terrace | | | |
| | e. Width of Corridor | 01m | 01m | MR |
| | f. Door Size | 1m | 1.05m | MR |
| 3 | Compartmentation. | | | |
| | <ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 4 | Smoke Management System. | | | |
| | <ul style="list-style-type: none"> Basements Upper floors | NA | NA | NA |
| | | Required | Natural Ventilation | MR |
| 5 | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> Total numbers | 04nos | 06nos | MR |

9

| | | | | |
|----|---|----------|----------|-----|
| | • Types | ABC/Co2 | ABC-06 | MR |
| | • ISI marking | Yes | Yes | MR |
| 6 | First-Aid Hose Reels. | | | |
| | • Total numbers on each floor | NA | NA | NA |
| | • Length of hose reel hose | NA | NA | NA |
| | • Nozzle diameter | NA | NA | NA |
| 7 | Automatic fire detection and alarming system | | | |
| | • Type of detectors | NA | NA | NA |
| | • Location of Main Panel | NA | NA | NA |
| | • Location of Repeater Panel | NA | NA | NA |
| | • Alternate source of power | NA | NA | NA |
| | • Hooters' Location | NA | NA | NA |
| 8 | MOEFA | Required | Provided | MR |
| 9 | Public Address System. | NA | NA | NA |
| 10 | Automatic Sprinkler System. | | | |
| | • Basement | NA | NA | NA |
| | • Upper Floor | NA | NA | NA |
| | • Sprinkler above false ceiling | NA | NA | NA |
| 11 | Internal Hydrants | | | |
| | • Size of riser/down-comer | NA | NA | NA |
| | • Number of hydrants per floor | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 12 | Yard Hydrants. | | | |
| | • Total number of hydrants | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 13 | Pumping Arrangements. | | | |
| | • Ground Level | | | |
| | ➤ Discharge of main Pump | N/A | N/A | N/A |
| | ➤ Head of Main pump | N/A | N/A | N/A |
| | ➤ Number of main pumps | N/A | N/A | N/A |
| | ➤ Jockey Pump out put | N/A | N/A | N/A |
| | ➤ Jockey pump head | N/A | N/A | N/A |
| | ➤ Standby Pump out put | N/A | N/A | N/A |
| | ➤ Standby Pump Head | N/A | N/A | N/A |
| | ➤ Auto Starting/ Manual stopping | N/A | N/A | N/A |
| | ➤ Pump House Access | N/A | N/A | N/A |
| | • Terrace level | | | |
| | ➤ Discharge of pump | NA | NA | NA |
| | ➤ Head of the pump | NA | NA | NA |
| | ➤ Power Supply | NA | NA | NA |
| | ➤ Auto Starting of pump | NA | NA | NA |
| 14 | Captive Water Storage for fire fighting. | | | |
| | • Underground tank capacity | NA | NA | NA |
| | ➤ Draw-off connection | NA | NA | NA |

| | | | | |
|----|--|----------|----------|-----|
| | <ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 15 | Exit Signage. | Required | Provided | MR |
| 16 | Provision of Lifts. | | | |
| | • Pressurization of Lift Shaft | N/A | N/A | N/A |
| | • Pressurization of Lift lobby | N/A | N/A | N/A |
| | • Communication In lift Car | N/A | N/A | N/A |
| | • Fireman's Grounding Switch | N/A | N/A | N/A |
| | • Lift Signage | N/A | N/A | N/A |
| 17 | Standby power supply | N/A | N/A | N/A |
| 18 | Refuge Area. | | | |
| | ➤ Total Area | N/A | N/A | N/A |
| | ➤ Location | N/A | N/A | N/A |
| 19 | Fire Control Room | | | |
| | • Detector System Panel | N/A | N/A | N/A |
| | • Flow Switch Panel | N/A | N/A | N/A |
| | • PA System Panel | N/A | N/A | N/A |
| | • Batter backup | N/A | N/A | N/A |
| | • Building Floor Plans | N/A | N/A | N/A |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | N/A | N/A | N/A |

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no. F6/DFS/MS/2022/School/WZ/333 dated 29.03.2022.

Signature of the Inspecting Officer
 Name :- C.L. Meena
 Designation :- ADO/RN

D.B. Mukharjee (DO/NW)

DCFO/ 1356-MW
 Dated 7/4/2022

By Cfo (NW)
 07/04/2022

Cfo/ 11/4/2022
 8/4/2022

Director/ 01/04/22

By Cfo

cont... P.T.O