



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/ 1234

Dated: 06/10/2025

FIRE SAFETY CERTIFICATE

Certified that the D.K. Convent School located at B- Block, Gali No.110, Sant Nagar, Burari, Delhi-110084 comprised of 01 blocks, Ground & 02 upper floors only owned/ occupied by D.K. Convent School was issued Fire Safety Certificated by this department vide letter F.6/DFS/MS/School/2022/WZ/705 dated 24/06/2022. The premises was inspected by the officer concerned of this department on 26/09/2025 in presence of Sh. Manish (Teacher) and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class "Group B Educational (School) for 01 blocks, Ground & 02 upper floors only" with effect from06.10.2025 for a period of three years, subject to compliance of the conditions mentioned below:

Issued on06.10.2025 at New Delhi by.

M.K. Chattopadhyay
Dy. Chief Fire Officer
Delhi Fire Service

Copy to :-

1. The Deputy Director of Education, GNCT of Delhi, Zone-VII, District North Lucknow Road, Timarpur, Delhi - 110054.
2. The Manager, D.K. Convent School located at B- Block, Gali No.110, Sant Nagar, Burari, Delhi-110084.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doit/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : D.K Convent School at B-Block, Gali No-110, Sant Nagar, Burari, Delhi-84.
2. Type of Occupancy : Educational
3. Composition of building : Ground & 02 upper floors
4. Type of Case : Renewal
5. Details of previous NOC : F.6/DFS/MS/School/2022/WZ/705 dated 24/06/2025
6. Fire Safety directives letter No : Nil
7. Date of inspection : 26/09/2025
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers
from the building side : Sh. Manish (Teacher)
10. Year of Construction : 2004 & 2005
11. Applicant's letter No. : Letter No. Nil & DFS Dairy No.6216 dated 19/09/2025


	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per Rules 35 (6)	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	5.10m	MR (being old case)
	• Gate width	Directly Accessible	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.20 & 1.07m (iron staircase)	MR(old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	Required	Provided	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	01m	01m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilated	MR
5	Fire Extinguishers			
	• Total numbers	07nos	12nos	MR
	• Types	ABC/Co2	ABC--12	MR
	• ISI marking	ISI Marked	Yes	MR

6	First-Aid Hose Reels.			
	<ul style="list-style-type: none">• Total numbers on each floor• Length of hose reel hose• Nozzle diameter	01	01	MR
		30m	30m	MR
		5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none">• Type of detectors• Location of Main Panel• Location of Repeater Panel• Alternate source of power• Hooters' Location	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none">• Basement• Upper Floor• Sprinkler above false ceiling	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none">• Size of riser/down-comer• Number of hydrants per floor• Hose Box	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none">• Total number of hydrants• Hose Box	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none">• Ground Level<ul style="list-style-type: none">➤ Discharge of main Pump➤ Head of Main pump➤ Number of main pumps➤ Jockey Pump out put➤ Jockey pump head➤ Standby Pump out put➤ Standby Pump Head➤ Auto Starting/ Manual stopping➤ Pump House Access	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none">• Terrace level<ul style="list-style-type: none">➤ Discharge of pump➤ Head of the pump➤ Power Supply➤ Auto Starting of pump	450 LPM	450 LPM	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none">• Underground tank capacity<ul style="list-style-type: none">➤ Draw-off connection➤ Fire service inlet➤ Access to tank• Overhead Tank capacity	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		5,000 LTR	5,000 LTR	MR (Being old case)
	15	Exit Signage	Required	Provided

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, **it is recommended for renewal of fire safety certificate** issued vide this department letter of even no. F.6/DFS/MS/School/2022/WZ/705 dated 24/06/2022.


 Signature of the Inspecting Officer
 Name :-C.L. Meena
 Designation:- ADO/RN

~~Dy.CFO (WZ)~~


 28/8

Cfo - NA

Principal Director

Dy. Cfo to

~~ADO (RN)~~

~~Dy. Cfo (WZ)~~

As approved, F.T. letter is kept up for your signature please.

~~Dy Cfo (WZ)~~

MSCey


 03/10/2025