



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/WZ/2025/ 634

Dated:- 11/08/2025

To,

The Principal,
D.M.C. Primary School (ID-1556392),
New Multan Nagar, Keshav Puram Zone, Delhi-110056.

Subj.:- Regarding renewal of Fire Safety Certificate in respect of D.M.C. Primary School (ID-1556392), located at New Multan Nagar, Keshav Puram Zone, Delhi-110056.

Sir,

Please refer to your Form 'J' dated 17/04/2025 received in this department through outdoor diary no. 798 dated 21/04/2025, on the subject cited above. In this connection, it is to inform you that the above said school building was re-inspected by the officer concerned of this department on 24/07/2025 in the presence of Sh. Arun Kumar Bhardwaj (Teacher) to check the compliance of shortcomings issued by this department vide letter no. F6/DFS/MS/WZ/2024/School/53 dated 14/02/2024 (copy enclosed).

During inspection, it have been observed that the shortcoming issued by this department vide above said letter has not been rectified yet.

In view of the above, the application for renewal of Fire safety Certificate **cannot be considered at this stage & rejected**. You are advised to rectify the above mentioned shortcoming under intimation to this department for taking further necessary action.

Yours faithfully,


Virendra Singh
Chief Fire Officer

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आगामी 1
1000 पत्राचार

No. F6/DFS/MS/W7/2024/ School | 53

Dated:- 14/02/2024

To,

The Principal,
North Delhi Nagar Nigam Vidyalaya (ID-1556392),
New Multan Nagar, Keshav Puram Zone, Delhi-110056.

Subj.:- Regarding renewal of Fire Safety Certificate in respect of North Delhi Nigam Vidyalaya (ID-1556392), located at New Multan Nagar, Keshav Puram Zone, Delhi-110056.

Sir,

Please refer to your letter no. nil dated 15/12/2023 received in this department outdoor diary no. 10894 dated 15/12/2023, on the subject cited above. In this connection, it is to inform you that the above said school building was re-inspected by the officer concerned of this department on 08/02/2024 in the presence of Sh. Sunil Drall (Teacher). During inspection, it has been observed that the school building is comprised of Ground + 01 upper floor. However, the following shortcoming has been observed:-

1. Electrical meters/panels found under the staircases same shall be shifted on another safe place.

In view of the above, the application for renewal of Fire safety Certificate cannot be considered at this stage & rejected. You are advised to rectify the above mentioned shortcoming under intimation to this department for taking further necessary action.

Yours faithfully,

(Sunil Gang)
Director

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.

82
08/02/24