



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001



No.F.6/DFS/MS/Metro/2025/NDZ/264

Dated: 10/06/2025

To,

Sr. Dy. General Manager/Elect/PD  
25, Ashoka Road, (Near Patel Chock, Metro Station),  
New Delhi 110001

**Subject: - Regarding renewal of Fire Safety Certificate in r/o DMRC IT Park Block No. 03, Shastri Park, Delhi, New Delhi-110053.**

Sir,

With reference to your letter no. DMRC/GM/PD-1/DFS/2025 dated 28/04/2025 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned premises from fire safety point of view on dated 02/06/2025 in presence of the Mr. Himanshu Bhardwaj (Estate Manger). The building comprised of two basement, ground plus eight upper floors only. Following shortcoming was observed during the time of inspection.

1. Pressurization system of lift shaft is provided but not functional.

In view of the above, the building cannot be considered for issuance of Fire Safety Certificate at this stage. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully

  
21/6/2025  
(VIRENDRA SINGH)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

Copy to:-

Sr. DGM/E&M  
Metro Bhawan, Fire Brigade Lane, New Delhi 110001