

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No.F.6/DFS/MS/Metro/2025/SZ/ 324

Dated: 13/06/2025

FIRE SAFETY CERTIFICATE

Certified that "DMRC Malviya Nagar Underground Metro Station" comprised of Ground, Concourse & Platform level owned/occupied by DMRC Delhi was issued Fire Safety Certificate by this department vide letter no F6/DFS/MS/Metro/2022/SZ/283 dated 24/06/2022. The premise was re-inspected by the officer concerned of this department on 10/06/2025 in the presence of Mr. Jagjeet Singh (JE) and found that the said metro station building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class-D "Assembly Occupancy Metro Railway" as above with effect from 13/06/2025 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 13/06/2025 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. Mr. Rajesh Aggarwal (GM/F&M) Delhi Metro Rail Corporation, Metro Bhawan, Fire Brigade Lane, New Delhi-110001.

Conditions for the validity of Fire Safety Certificate: -

1. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
2. All the staff members must know the correct method of operation of fire fighting system.
3. The basement shall be used strictly as per the provision of Building Bye Laws.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	DMRC Malviya Nagar Underground Metro Station (line-2)		
2	Type of Occupancy	Assembly (D-7)		
3	Building Comprised of	Ground floor, Concourse & Platform level.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/Metro/2022/SZ/283 dated 24/06/2022		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	10-06-2025		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Jagjeet Singh (JE)		
10	Year of construction	2010		
11	Applicant letter No.	Outdoor diary no 1152 dated 29/04/2025		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old FSC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	As per PWD	YES.	MR
	• Gate width	Required	Approx 6mtrs	MR
	• Width of internal road	Required	6mtrs	MR
2	Number, width, type & arrangements of exits			
	a. Number of Staircase			
	➤ Upper floors	N/A	N/A	N/A
	➤ Basement floor	Required	03(Platform to concourse) 03(concourse to ground) EMR south (Concourse to Ground)	MR
	b. Width of Staircase			
	➤ Upper floors	N/A	N/A	MR
	➤ Basement floor	Required	PF- CC -3.6 mtr.(3 nos) CC-Ground- 4.00m (2nos),CC -Ground 2.55 EMG Exit PF-CC-2.35mtr (2 nos)	MR
	c. Protection of exits			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	Required	Provided in Firemen & emergency staircase	MR
	d. No. of continuous staircase to terrace	Required	6 staircases	MR
	e. Width of corridor	As per NFPA	Provided	MR
	f. Door size	Required	1.9 m (emergency exit)	MR
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	Required	2 hrs	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	Required	provided	MR
4	Smoke Management system.			
	• Basement	Required	4 nos Tunnel ventilation fans & 6 nos Track way exhaust fans provided	N/A
	• Upper floors	N/A	N/A	N/A
5	Fire Extinguishers.			
	• Total numbers	90 Nos :- Co2 Ext. -68, ABC Ext- 20, water 02	Provided	MR
	• Types		Provided	MR
	• ISI Marking		Provided	MR

6	First Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor. Length of hose-reel hose. Nozzle Diameter 	05 (Each Platform), 09 (Concourse level) 1 ECS (north & south) 1 ANC	Provided	MR
		30 mtrs	Provided	MR
		5mm	Provided	MR
7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	Required	Smoke & Heat detector provided	MR
		Required	Provided at Station Control Room	MR
		Required	Provided in Firemen staircase	MR
		Required	Provided	MR
		Required	Provided at platform and concourse level	MR
8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	Required	Provided at platform	MR
		Required	Provided	MR
		N/A	N/A	N/A
11	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	80 mm	Provided	MR
		Required	Provided Platform each-5, Concourse- 9,ECS north & South(1)	MR
		Required	As above.	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	Required	Provided-3 nos.	MR
		Required	Provided-3 nos.	MR
13	Pumping arrangements.			
	a) Ground Level			
	➤ Discharge of main pump.	2859 lpm	Provided	MR
	➤ Head of main pump.	75 mts.	Provided	MR
	➤ Number of main pumps.	02	Provided	MR
	➤ Jockey Pump output.	189 LPM	Provided	MR
	➤ Jockey Pump head.	56 mts.	Provided	MR
	➤ Standby Pump output.	2859LPM	Provided	MR
	➤ Standby Pump head.	56 mts	Provided	MR
	➤ Auto Starting/Manual Stopping.	Required	Provided	N/A
	➤ Pump House Access	Required	Provided	N/A
	b) Terrace Level			
	➤ Discharge of pump.	N/A	N/A	N/A
	➤ Head of pump.	N/A	N/A	N/A
	➤ Power supply.	N/A	N/A	N/A
	➤ Auto starting of pump.	N/A	N/A	N/A
14	Captive water storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. ➤ Draw-off connection. ➤ Fire Service Inlet. ➤ Access to tank. Overhead tank capacity. 	100 KL.	Provided	MR
		Required	Provided 01 no near fire tank	MR
		Required	Provided	MR
		Required	Provided	MR
		N/A	N/A	N/A
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. 	N/A	N/A	N/A

	Pressurization of lift lobby.	N/A	N/A	N/A
	Communication in lift car.	Required	Provided	MR
	Fireman's switch.	Required	Provided	MR
	Lift signage.	Required	Provided	MR
		Required	Provided (DG Set)	MR
17	Standby Power Supply			
18	Refuge Area	N/A	N/A	N/A
	Total area	N/A	N/A	N/A
	Location			
19	Fire Control Room.	Required	Provided	MR
	Detector System Panel.	Required	Provided	MR
	Flow Switch Panel.	Required	Provided	MR
	PA system Panel.	Required	Provided	MR
	Battery backup	Required	Provided	MR
	Building floor plan	Required	Provided	MR
20	Special Fire Protection System for the Protection of Special Risk, if any	ASS North, ASS South - Total Gas flooding system.		MR

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/Metro/2022/SZ/283 dated 24/06/2022, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

AS
11/6/22

Signature of Inspecting Officer
Name: Rajesh Kumar
Design: ADO (BCP)

DO (SD)

mm/11/6/22

CHO
12/6/2022

Director
11/6/22

AD/BCP

*As approved, F.T. letter is put up for
your signature P1*

Director
11/6/22

11/6/22