



C/180

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001


No. F6/DFS/MS/Metro/2025/NDZ/ 403

Dated: 01/08/2025

FIRE SAFETY CERTIFICATE

Certified that the DMRC Maujpur Elevated Metro Station Building Line-7, Delhi, comprised of Ground level + Concourse level + Platform level owned/occupied by Delhi Metro Rail Corporation was issued FSC vide letter No. F.6/DFS/MS/DMRC/2022/NDZ/338 dated 29/04/2022. The premises was re-inspected by the officer concerned of this department on 14/07/2025 in the presence of Mr. Pushkar, (AM/Fire) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules 2010 and that the building is fit for occupancy class 'Assembly' (class "D") with effect from 01/08/2025 for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on 01/08/2025 at New Delhi by.


30/08/2025
(VIRENDRA SINGH)
CHIEF FIRE OFFICER

To,
The Sr. DGM/E&M
Metro Bhawan 13 Fire Brigade Lane
New Delhi 110001

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

N/20.

1. Name & address of the building : Maujpur Elevated Metro Station Building Line-7, Delhi
2. Building is comprised of : Road Level(GF) + Concourse level + Platform level
3. Type of Occupancy : Assembly building
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/DMRC/2022/NDZ/338 dt 29/04/2022
6. Fire Safety directive letter No. : F6/DFS/MS/BP/2018/2953 dated 11/07/2018
7. Date of Inspection : 14/07/2025
8. Name of the Inspecting officers : ADO (Shd.) Deepak Kumar
9. Name and designation of Officer from the building side : Mr. Pushkar (AM/Fire)
10. Year of Construction :
11. Applicant's letter No : DMRC/O&M/Fire/NOC/Line-7/2025/05/47
- Dated- 27/05/2025

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	As per Directive Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	06 mtr.	19.50 mtr.wide main road	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper floor	11 nos.	11 nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases	11	G to C (4010 m, 1.85m, 1.85m, 2.54 m, 2.74 m + 02 ESC) C to P (2.30 m, 3.65m, 2.90m, 3.10m, 2.80m, 2.70m + 04 ESC)	MR
	• Upper floor			
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	N/A	N/A	N/A
	e. Width of Corridor	1.50 mtr	Provided	MR
	f. Door Size	02 mtr.	02 mtr. & 1.50 mtr	MR
03	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Sealed	MR
	• Fire rating of shaft door	02 nos.	02 nos.	MR
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	Required	Natural Ventilated	MR
05.	Fire Extinguishers			
	• Total numbers	22 nos.	31 nos	MR
	• Types	ABC /CO ₂	ABC & CO ₂	MR
	• IS marking	ISI marked	Provided	MR

25

06	First-Aid-Hose Reels.			
	Total numbers on conc. & Platform	04 nos. C to P 09 P level	04 nos. C to P 09 P level	MR
	• Length of hose reel hose	45 mtr	45 mtr	MR
	• Nozzle diameter	6.50 mm	6.50 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	Heat/Smoke	Provided	MR
	• Location of main panel	Required	Concourse level (Station Control room)	MR
	• Location of repeater panel	Required	Provided	MR
	• Alternate source of power	Battery & DG set	Provided	MR
	• Hooter	N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	13 nos.	13 nos.	MR
	• Hose box	13 nos.	13 nos.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	1800 LPM	1800 LPM	MR
	• Head of main pump	70 M	70 M	MR
	• Number of main pumps	01 nos	01 nos	MR
	• Jockey pump out put	180 LPM	180 LPM	MR
	• Jockey pump head	70 M	70 M	MR
	• Standby pump out put	1800 LPM	1800 LPM	MR
	• Standby pump head	70 M	70 M	MR
	• Auto starting /manual stopping	Required	Provided	MR
	• Pump house access	Required	Provided	MR
	➤ Terrace Level			
	• Discharge of pump	N/A	N/A	N/A
	• Head of the pump	N/A	N/A	N/A
	• Power supply	N/A	N/A	N/A
	• Auto starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	50,000 ltr	5,000 ltr	MR
	• Draw-off connection	Required	Provided	MR
	• Fire service inlet	Required	Provided	MR
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	10,000 ltr	10,000 ltr	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	Required	Provided	MR
	• Firemen's grounding switch	Required	Provided	MR
	• Lift signage	Required	Provided	MR
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	Required	Provided	MR
	• Flow switch panel	Required	Provided	MR
	• PA system panel	Required	Provided	MR
	• Battery backup	Required	Provided	MR
	• Building floor plans	Required	Provided	MR
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	Required	NOVEC 1230 clean agent	MR

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the Rules. The FSC issued vide letter No. F.6/DFS/MS/DMRC/2022/NDZ/338 dated 29/04/2022 renewal under rule 37 of the Delhi Fire Service Rule, 2010 is recommended.

Deepak
14/07/2025

Signature of the Inspecting Officer

Name : - Deepak Kumar

Designation : - A.D.O (Shd)

DO/ED

APB

14.7.2025

By CFO/NDZ

KMP
15/7/25

C.F.O.

High
22/7/2025

Principal Director

CFO to Sdme.

Q
22/5/25

QFO

Wd
23/7/2025

ADD (Shah)