



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Metro/2025/SZ/ 81

Dated: 18/02/2025

FIRE SAFETY CERTIFICATE

Certified that the **DMRC Metro Station** located at Sector-14, Dwarka, New Delhi-110078, comprised of Ground + 01 upper floor, owned/occupied by Delhi Metro Rail Corporation, was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/SZ/2022/135 dated 30/03/2022. The premise was re-inspected by the officer concerned of this department on 27/01/2025 in presence of Mr. Sunil (Inspector/Fire) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Assembly Group D-7**" (Metro Station) with effect from 18/02/2025 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 18/02/2025 at New Delhi by

(ATUL GARG)
DIRECTOR

T. No. 011-23414000

Copy to: -

1. Sh. Rajesh Agarwal (GM/Elect & Mech), Delhi Metro Rail Corporation Limited, Metro Bhawan, 13, Fire Brigade Lane, Barakhamba Road, New Delhi-110001

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. Any deviation with regard to construction, ventilation, occupancy, electric installation etc., may be got verified from concerned authorities.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, prior to its expiry".

N-15

INSPECTION REPORT				
1.	Name & address of the building	DMRC Metro Station located at Sector-14, Dwarka New Delhi-110078		
2.	Type of Occupancy	Assembly "Group D-7" (Metro Station)		
3.	Building Comprised of	Ground + 01 upper floor.		
4.	Type of Case	Renewal		
5.	Details of previous NOC No.	F6/DFS/MS/SZ/2022/135 dated 30/03/2022		
6.	Fire Safety directives Letter No.	NBC Part-IV		
7.	Date of inspection	27/01/2025		
8.	Name of the Inspecting Officer	ADO (SJ)		
9.	Name and designation of Officer from the building side	Sh. Sunil (Inspector/Fire)		
10.	Year of Construction	2006		
11.	Applicant's letter No./Online Appn.	Outdoor Diary No. 10966 dated 03/01/2025		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	09 mtr	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	Required	04 Nos (Concourse to Platform)	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	Required	Provided	MR (old case)
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of Corridor	2 mtr	2.5 mtr	MR
	f. Door Size	1.5 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Managements System			
	• Basement.	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	Required	32 Nos	MR
	• Types	ABC/CO ₂ /W CO ₂	CO ₂ & W CO ₂	MR
	• ISI marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	02 Nos at each platform & 2 Nos at Ground Floor	Provided	MR
	• Length of hose reel hose	45 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR

87

7.	Automatic fire detection and alarming system.			
	• Type of detector	Required	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Platform & Concourse level	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down- comer	150 mm	Provided	MR
	• Number of hydrants per floor	Required	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	Required	Provided	MR
	• Hose Box	Required	Provided	MR
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	1800 LPM	Provided	MR
	➤ Head of main pump	60m	Provided	MR
	➤ Number of main pumps	One	Provided	MR
	➤ Jockey pump out put	180 LPM	Provided	MR
	➤ Jockey pump head	60m	Provided	MR
	➤ Standby Pump out put	1800 LPM	Provided	MR
	➤ Standby Pump Head	60m	Provided	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
14.	Captive water storage for firefighting			
	• Underground tank capacity	50,000 Ltr	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	N/A	N/A	N/A
15.	Exit signage	Required	Provided	MR
16.	Provision of lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A

N-17

19.	Fire Control Room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	Required	Auto and manual CO ₂ trace tube flooding system provided for HT/LT electric panel	MR

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety as required under the rules, the fire safety certificate issued vide letter No. F6/DFS/MS/SZ/2022/135 dated 30/03/2022, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Suman
07.02.25
Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (SJ)

DO (SW)

11/2/25

C.F.D. 11/2/25

Director

Sir, F.T. notes is pump for your Sing. pl

Director

Suman
13.02.25