



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

77. C/24
आजादी
अमृत महोत्सव

No. F6/DFS/MS/Metro/WZ/2025/ 427

Dated:- 11/08/2025

FIRE SAFETY CERTIFICATE

Certified that the **DMRC Udyog Nagar Metro Station (Elevated)** Located at **Udyog Nagar, New Delhi-110041** comprised of **Ground, 1st floor (Concourse Level) & 2nd floor (Platform Level)** owned/occupied by **Delhi Metro Rail Corporation Ltd.** was issued Fire Safety Certificate by this department vide letter no. **F6/DFS/MS/Metro/WZ/2022/415** dated **21/09/2022**. The said building/Premises was re-inspected by the officer concerned of this department on **30/07/2025** in the presence of **Sh. Ashish Antil (Sr. Fire Inspector) & Sh. Pushkar Singh (Assist. Manager Fire)** and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010, and that **the building is fit for occupancy Group – D 'Assembly' (Except PD Area)** with effect from **11/08/2025**..... for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010 printed below..

Issued on **11/08/2025** at New Delhi by

Virendra Singh
Chief Fire Officer

08/08/25

Copy to:

1. Sh. Rajesh Agrawal (GM/E&M) , Metro Bhawan, 13 Fire Brigade Lane, Barakhamba Road, New Delhi-110001.

Conditions for validity of fire safety certificate:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building: DMRC Udyog Nagar Metro Station, Udyog Nagar, New Delhi 110041.
2. Type of Occupancy : Assembly (Metro Station)
3. Type of Case : Renewal, Ground + 1st floor (Concourse Level) & 2nd floor (Platform Level)
4. Details of previous NOC : F6/DFS/MS/Metro/WZ/2022/415 dated 21/09/2022
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2008/120 dated 16.01.2008
6. Date of inspection : 30/07/2025
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer from the building side : Sh. Ashish Antil (Sr. Fire Inspector) & Sh. Pushkar Singh (Assist. Manager Fire)
9. Year of Construction : 2009-10
10. Applicant's letter No. : DMRC/O&M/Fire/NOC/L-3/2025/18 dated 07/07/2025

S No	Minimum standards on fire prevention and fire safety U/R 33	NFPA/NBC Requirements/as per earlier FSC issued dated 21/09/2022	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	On Main Road	On Main Road	MR
	• Gate width	05 m	On Main Road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02+04	02+04	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	02 m x 2 (Ground to 1 st floor) 04 m x 2 & 02 m x 2 (Concourse to Platform Level)	Ground to 1 st floor = 2.10 m x 2 1 st to 2 nd floor = 4.10 m x 2 & 2.10 m x 2	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1.5 m	Hall	MR
	f. Door Size	1 m	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA



5.	Fire Extinguishers			
	• Total numbers	20 Nos.	36 nos.	MR
	• Types	ABC, CO2	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	02 & 04	Provided	MR
	• Length of hose reel hose	45 m	Provided	MR
	• Nozzle diameter	6.5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	150 mm	Provided	MR
	• Number of hydrants per floor	02 & 04	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	Required	Provided	MR
	• Hose Box	Required	Provided	MR
13.	Pumping Arrangements:			
	• Ground Level			
	➤ Discharge of main pump	1800 lpm	Provided	MR
	➤ Head of main pump	60 m	Provided	MR
	➤ Number of main pumps	01	Provided	MR
	➤ Jockey pump out put	180 lpm	Provided	MR
	➤ Jockey pump head	60 m	Provided	MR
	➤ Standby Pump out put	1800 lpm	Provided	MR
	➤ Standby Pump Head	60 m	Provided	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	➤ Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting:			
	➤ Under ground tank capacity	50,000 ltrs.	Provided	MR
	➤ Draw off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	➤ Overhead Tank capacity	NR	NR	NR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR

18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required in electrical panels/station etc.	Provided	MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view deemed compliance of the minimum standards of fire prevention and fire safety requirements under the rules, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/Metro/WZ/2022/415 dated 21/09/2022 is **recommended** under rules 37 of the Delhi Fire Service rules 2010 under the DFS Act 2007.

Accordingly DFA is prepared & put up for approval please.

Aman Kumar Lathar
ADO (JWP)

Handwritten signature

Handwritten signature
31/7/2025

Handwritten signature
4/8/2025

Principal Director

Handwritten signature
CFO to Secy.

Handwritten signature
24/08/25

Handwritten signature
CFO

ADO (JWP)

Sir, FF. Letter is added for your signature pl.

Handwritten signature

Handwritten signature
9/8/2025

Handwritten signature
24/08/25
ADO (JWP)