



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



NoF6/DFS/MS/NZ/BNQT/2026/ 674

Dated: 13/07/2026

To

The Commissioner,
Municipal Corporation of Delhi,
Dr. SPM Civic Centre, New Delhi - 110002.

Sub:-Regarding renewal of Fire Safety Certificate in r/o M/s Cling Kitchen And Bar (A Unit of NGR Hospitalities Pvt. Ltd.) located at Prop. No. 21 and 31, 3rd Floor, Mall Road Near D.U. Metro Station, Delhi - 110054.

Sir,

This has reference to MCD online application ID No. 2026061008635 dated 10.06.2026 on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 22.06.2026 in presence of Manager and it was observed that the building is comprised of Basement + ground + 03 upper floors but restaurant is running at 3rd floor only and have complied the shortcomings issued vide letter no. F6/DFS/MS/EH/WZ/2026/397 dated 28.04.2026 except following which still exist:

1. Fire check door removed in the kitchen area.
2. Diesel driven engine fire pump of 2280 LPM capacity found removed.
3. Fire pumps of both underground and overhead tanks not on auto start mode.
4. Communication system in the lift car found removed.
5. Lift signages found removed.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to:-

The Licensee,
M/s Cling Kitchen And Bar (A Unit of NGR Hospitalities Pvt. Ltd.) at Prop. No. 21 and 31, 3rd Floor,
Mall Road Near D.U. Metro Station, Delhi - 110054.