



C-52



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F.6/DFS/MS/BNQT/NDZ/2026/ 336

Dated: 16/04/2026

To,

Mr. Rakesh Nagpal,
M/s Kanishka Banquet,
Property No. D35 -36,
Main Road Kanti Nagar,
Delhi-110051.

Subject: -M/s Kanishka Banquet located at Property No. D 35-36, Main Road Kanti Nagar, Delhi-110051.

Sir,

This has reference to MCD application ID No. 2026030302303 dated 05/03/2026 on the subject cited above. In this connection, the premises have been inspected by the officer concerned of this department on dated 04/04/2026 in presence of Mr. Anil, Manager. The Banquet Hall building is comprised of basement, ground plus two upper floors but Banquet is running at ground floor and one upper floor only. The following shortcoming was observed during the time of inspection.

1. Smoke Management system in the upper floors found removed.
2. Fire extinguishers found empty.
3. First-Aid-Hose Reels are provided but not functional.
4. MOEFA found removed.
5. Internal hydrant provided but not functional.

In view of above shortcomings, the application for issuance Fire Safety Certificate is **rejected**. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


16/4/26

(Dr. S. K TOMAR)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

o/c