

C-41

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/NDZ/2025/251

Dated: 26/06/2025

To

The Manager,
VVL Group (Night Riders),
J-2/1, B.K. Dutt Market, Rajouri Garden,
Delhi-27.

Sub: Regarding renewal of Fire Safety Certificate in r/o M/S VVL Group (Night Riders),
J-2/1, B.K. Dutt Market, Rajouri Garden, Delhi-27.


Sir,

This has reference to online ID No . 2025051308369 dated 13.05.25, on the subject cited above, it is to inform you that the site was inspected by the officers concerned department on 31/05/2025 in the presence of Mr. Lucky and the following shortcomings were observed:-

1. Hose reel, Pump & Hydrant found nonfunctional.
2. MCP found removed.
3. Exit door of 1.20 m is provided against the requirements of 2.0 meter.
4. Restaurant running 1st, 2nd & 3rd floor, whereas, in application form applicant has applied 1st & 2nd floor. Hence, building plan of the premises including section /elevation with duly signed by architect & owner is also required to be upload on the portal, to assess the fire safety arrangements according to height of the building,

In view of above, Fire Safety Certificate cannot be renewed. Therefore, you are requested to rectify the above shortcomings for further consideration in the matter. Further, the occupancy of the building/premises in absence of requisite fire safety arrangements shall be at risk and liability of owner/occupier. The licensing /statuary authority may take suitable necessary action as deemed fit.

Yours faithfully


51/6/2025
(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to :-

The Jt. commissioner of Police, Licensing Unit, Defense Colony Police Station,
New Delhi.