



75  
Azadi Ka  
Amrit Mahotsav

c-32

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/School/2025/SZ/ **509**

Dated: 10/06/2025

To

The General Manager,  
Basava International School,  
Plot No. 1, Sector-23,  
Dwarka, New Delhi-110077

Sub: **Renewal of Fire Safety Certificate in r/o Basava International School located at Plot No. 1, Sector-23, Dwarka New Delhi-110075**



Sir,

Please refer to your email dated 20/05/2025, on the subject cited above. In this connection, the school premise was inspected by the officer concerned of this department on 30/05/2025 from fire safety point of view, in your presence and the shortcomings observed are as below.

1. First aid hose reel found non-functional.
2. Terrace level fire pumps provided found non-functional.
3. Overhead water tank for firefighting found empty.
4. Exit signage's found removed at some locations.

In view of above, the application for renewal of fire safety certificate is rejected. You are advised to rectify the shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

  
**(Virendra Singh)**  
Chief Fire Officer  
Delhi Fire Service  


Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054