



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No F.6/DFS/MS/EH/SZ/2026/ 376

Dated: 21/04/2026

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the Name & Style of M/s. Dominos Pizza, (Jubilant Foodworks Limited) located at Ground Floor, 05, Paras Cinema, Nehru Place, New Delhi-110019, in a building comprised of basement, ground, mezzanine plus three upper floors. Owned/Occupied by Jubilant Foodworks Limited, earlier Fire Safety Certificate issued by this department vide letter no. F.6/DFS/MS/EH/2023/SZ/323 dated-31/10/2023. The premises was re-inspected by the officer concerned of this department on 13/03/2026 in the presence Sh. Yunus Khan. and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premise is fit for occupancy Class (Group-D) (Assembly Building) (Restaurant at ground floor only) with effect from 21/04/2026 for the period of three years, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 21/04/2026 at New Delhi by


(A.K. Malik)
Chief Fire Officer

ac 849

Copy to:

1. The Commissioner MCD, Civic Centre, Minto Road, New Delhi- 110002.- to ensure the occupancy as detailed above & deviation if any.
2. The authorized signatory, M/s. Dominos Pizza, (Jubilant Foodworks Limited) at Ground Floor, 05, Paras Cinema, Nehru Place, New Delhi-110019. (Online Portal ID No. -2026032303429 dated-23/03/2026).

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to nonfunctional fire safety measure shall be at the responsibility of the management/occupier.
3. The trained firefighting staff should be available round the clock.
4. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.
9. Basement shall be used as per building by laws strictly.

N/10

INSPECTION REPORT

1. Name & address of the building	M/s. Dominos Pizza, (Jubilant Foodworks Limited) located at Ground Floor, 05, Paras Cinema, Nehru Place, New Delhi-110019.			
2. Type of Occupancy	Group-D (Assembly Building, Restaurant at GF only), comprised of Basement, Ground, Mezzanine plus Three Upper Floor.			
3. Type of Case	Renewal			
4. Details of Previous NOC	F.6/DFS/MS/EH/2023/SZ/323 dated-31/10/2023.			
5. Fire Safety directives letter No	Nill			
6. Date of inspection	13/03/2026.			
7. Name of Inspecting Officer	Sh. Sarabjeet Singh ADO (BCP)			
8. Name and designation of officers From the building side	Sh. Yunus Khan.			
9. Year of Construction	2000 As per online application			
10. Applicant's letter No.	Online-ID No -2026032303429 dated-23/03/2026.			
S. No	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC/ as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1.	Access to building. FSC No.F.6/DFS/MS/Assembly/2022/SZ/Cinema/17 dated-07/01/2025 Paras Cinema District Centre Nehru Place, Kalkaji.			
	• Road width	12m	Provided*	MR
	• Gate width	4.5m	Provided*	MR
	• Width of internal road	06m	Provided*	MR
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	Provided & Maintained by Paras Cinema		
	• Upper Floors	NA	Restt. At GF	NA
	• Basements	NA	NA	NA
	b. Width of staircases	Provided & Maintained by Paras Cinema		
	• Upper Floor	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits	Provided & Maintained by Paras Cinema		
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	Required	Provided*	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.50mtr each	2x1.50m	MR
3.	Compartmentation			
	a) Fire check door	NA	NA	NA
	b) Sealing of electrical shafts	NA	NA	NA
	c) Fire Rating of shaft door	NA	NA	NA
	d) Water Curtain	NA	NA	NA
	e) Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	a) Basements	NA	NA	NA
	b) Upper floors	Required	Provided*	MR
5.	Fire Extinguishers			
	a) Total numbers	06 Nos	06 Nos. Provided	MR
	b) Types	ABC/CO ₂	ABC-04 & CO ₂ -02	MR
	c) IS marking	ISI marked	Provided	MR

Provided & Maintained by Paras Cinema			
6.	First-Aid Hose Reels		
	a) Total numbers on each floor	01 No near restt.	Provided*
	b) Length of hose reel hose	30mm	Provided*
	c) Nozzle diameter	5m	Provided*
7.	Automatic fire detection and alarming system		
	a) Type of detectors	NA	As above
	b) Location of Main Panel	NA	As above
	c) Location of Repeater Panel	NA	NA
	d) Alternate source of power	NA	NA
	e) Hooters' Location	NA	NA
8.	MOEFA	Required	Provided
9.	Public Address System	NA	As above
10.	Automatic Sprinkler System		
	a) Basement	NA	As above
	b) Ground & Upper Floors	Required	Provided*
	c) Sprinkler above false ceiling	NA	As above
11.	Internal Hydrants		
	a) Size of riser/down-comer	01 Required	Provided*
	b) Number of hydrants per floor	01 Required	Provided*
	c) Hose Box	01 Required	Provided*
12.	Yard Hydrants		
	a) Total number of hydrants	NA	As above
	b) Hose Box	NA	As above
13.	Pumping Arrangements		
	Provided & Maintained by Paras Cinema		
	• Ground Level		
	➤ Discharge of main Pump	NA	2280 LPM
	➤ Head of Main pump	NA	60 m
	➤ Number of main pumps	NA	02
	➤ Jockey Pump out put	NA	180 LPM
	➤ Jockey pump head	NA	60 m
	➤ Standby Pump out put	NA	2280 LPM
	➤ Standby Pump Head	NA	60 m
	➤ Auto Starting/Manual Stopping	NA	Provided*
	➤ Pump House Access	NA	Provided*
	Terrace level		
	➤ Discharge of pump	450LPM	As above
	➤ Head of the pump	40m	As above
	➤ Power Supply	Required	Provided*
	➤ Auto Starting of pump	Required	Provided*
14.	Captive Water Storage for firefighting		
	Provided & Maintained by Paras Cinema		
	• Underground tank capacity	NA	75,000 ltrs
	➤ Draw-off connection	NA	Provided*
	➤ Fire service inlet	NA	Provided*
	➤ Access to tank	NA	Provided*
	• Overhead Tank capacity	20,000 ltrs	As above
15.	Exit Signage.	Required	Provided
16.	Provision of Lifts.		
	Provided & Maintained by Paras Cinema		
	a) Pressurization of Lift Shaft	NA	NA
	b) Pressurization of Lift lobby	NA	NA

27/12

	c) Communication In lift Car	NA	NA	NA
	d) Fireman's Grounding Switch	NA	NA	NA
	e) Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided DG set	MR
18.	Refuge Area.			
	a) Total Area	NA	NA	NA
	b) Location	NA	NA	NA
19.	Fire Control Room	Provided & Maintained by Paras Cinema		
	a) Detector System Panel	NA	As above	NA
	b) Flow Switch Panel	NA	As above	NA
	c) PA System Panel	NA	As above	NA
	d) Battery backup	NA	As above	NA
	e) Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	As above	NA

Note- *Fire safety arrangements provided & maintained by Provided & Maintained by Paras Cinema, Nehru Place, New Delhi-110019.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F.6/DFS/MS/EH/2023/SZ/323 dated-31/10/2023, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signatures please.

Last date of disposal-21/04/2026

SAS
15/4/2026
Name - Sarabjeet Singh
Designation - ADO(BCP)

DO (SD) *[Signature]*
14/4/26
Ravinder Singh

[Signature]
16/4/26
A.K. MALIK
Principal Director

[Signature]
24/4/26
A.K. MALIK

[Signature]
24/4/26
A.K. MALIK

[Signature]
17/04/26