



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/2025/WZ/ Sch | 812  
To,

Dated: 17/11/2025

The Manager,  
Doon Public School,  
B-2, Paschim Vihar,  
New Delhi-110063.

Sub:- Renewal of Fire Safety Certificate in respect of Doon Public School located at  
B-2, Paschim Vihar, New Delhi- 110063.

Sir,


This has reference to your letter no. 5849/DPS/2025 dated 14/10/2025 received through outdoor diary no. 7135 dated 16/10/2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 06.11.2025 to see the compliance of the requisite fire safety measures. Mr. Suresh was present at the time of inspection.

During the course of inspection it was observed that the school building is comprised of Ground and Three upper floors (Except Three Blocks BL-1= G+1 (Sports faculty), BL-2= B+G+1 & BL-3= G+2 (Music Faculty). Your request for renewal of FSC is rejected as the following shortcomings were observed:-

1. Staircase found blocked by furniture.
2. First aid hose reels found provided but not functional.
3. Terrace level pumps not found in auto mode.
4. Overhead tank found empty.
5. Exit signages found removed at some places.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully

  
14/11/25

(S.K. Dua)  
Dy. Chief Fire Officer  
West Zone

