



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/WZ/2026/ 505

Dated: - 23/05/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Dr. S.P.M. Civic Centre, Minto Road,
New Delhi -110002.

Sub:- Regarding issuance of Fire Safety Certificate in r/o M/s. Dot Delhi Bar, located at Anchor GB-2, Sawasdee Amaber, Azadpur Metro Station, Delhi-110033.

Sir,

This has reference to online application no. 2026042305620 dated 23/04/2026 on the subject cited above. In this connection, it is to inform you that the said building was re-inspected by the officers concerned of this department on 07/05/2026 in the presence of Sh. Om Singh Srinet (Owner). During inspection, it was observed that the above said restaurant is running at ground floor only in a building comprised of basement + ground + 01 upper floor. After inspection, the following shortcoming were observed: -

1. The width of the alternate exit door is 1.50 m instead of the required width of 2.0 m.

In view of the above shortcomings, the application for issuance of Fire Safety Certificate cannot be considered at this stage & **rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(S.K. Dua)

Chief Fire Officer
Delhi Fire Service



Copy to: -

1. The Authorized Signatory, M/s. Dot Delhi Bar, located at Anchor GB-2, Sawasdee Amaber, Azadpur Metro Station, Delhi-110033.