



No. F6/DFS/MS/School/NDZ/2025/ 511

Dated: 22/04/2025

FIRE SAFETY CERTIFICATE

Certified that the **St. D.P.S. Model School** located at **A-8/652, Main 20 Foota Road, Meet Nagar, Delhi-110094.**, building comprised of ground plus two upper floors only, owned / occupied by **St. D.P.S. Model School**, was issued FSC vide letter No. F6/MS/DFS/2006/2546 dated 15/09/2006. The School building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and re-inspected by the officer concerned of this department on 15/04/2025 in presence of Mr. Yogender Kumar (Manager) of the school and that the school building is fit for occupancy class **"Educational Building" (Group - B)"** for with effect from 22/04/2025 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 22/04/2025 at New Delhi by.

(ATUL GARG)
DIRECTOR

OK DELHI FIRE SERVICE

Copy to:-

1. The Director of Education, Delhi Municipal Corporation, 419, Udyog Sadan, Patparganj Industrial Area, Delhi-92.
2. The Manager, St. D.P.S. Model School located at A-8/652, Main 20 Foota Road, Meet Nagar, Delhi-110094.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	St. D.P.S. Model School located at A-8/652, Main 20 Foota Road, Meet Nagar, Delhi-110094.		
2	Building is comprised of	Ground + Two Upper Floors		
3	Type of occupancy	Educational Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/MS/DFS/2006/2546 dated 15/09/2006		
6	Fire safety directives letter no.	Circular No.262-362 dated 17/01/2005		
7	Date of inspection	15/04/2025		
8	Name of the inspecting officers	Yashwant Singh Meena ADO, Laxmi Nagar		
9	Name of the designation of officer from the building side	Mr. Yogender Kumar (Manager)		
10	Year of construction	2000		
11	Applicant's letter no.	Outdoor diary no. 12528 dated 17/02/2025		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Circular Requirement	Provided at site	Remarks MR/NMR
1	Access to Building:			
A	Road width	6.0 meters.	6.0 meters.	MR
B	Gate width	N/A	N/A	N/A
C	Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:			
A	Number of staircases			
a	Upper floor	01 no.	02 no.	MR (Old Case)
b	Basement	N/A	N/A	N/A
B	Width of staircases			
a	Upper floor	1.5 meters.	0.70 meter. & 0.75 mtrs (Iron)	MR (Old Case)
b	Basement	N/A	N/A	N/A
C	Protection of exits			
a	Fire check door	N/A	N/A	N/A
b	Pressurization	N/A	N/A	N/A
D	No. of continuous staircases to terrace	01 no.	01 no.	MR
E	Width of corridor	1.5 mtrs.	2.10 mtrs.	MR
F	Door size	1.0 mtr.	1.0 mtr.	MR
3	Compartmentation:			
A	Fire check door	N/A	N/A	N/A
B	Sealing of electrical shafts	N/A	N/A	N/A
C	Fire rating of shaft door	N/A	N/A	N/A
D	Water curtain	N/A	N/A	N/A
E	Fire dampers	N/A	N/A	N/A
4	Smoke Management System:			
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A

5.	Fire Extinguisher:				
	A	Total numbers	08 nos.	08 nos.	MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C	ISI marking	ISI Marked	Provided	MR
6	First-Aid-Hose Reel:				
	A	Total numbers of each floor	01 no.	01 no.	MR
	B	Length of hose reel hose	30 mtr.	30 mtr.	MR
	C	Nozzle diameter	05 mm	05 mm	MR
7	Automatic Fire Detection and Alarming System:				
	A	Type of detectors	N/A	N/A	N/A
	B	Location of main panel	N/A	N/A	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	N/A	N/A	N/A
	E	Hooters	N/A	N/A	N/A
8	MOEFA:		N/A	N/A	N/A
9	Public Address System:		N/A	N/A	N/A
10	Automatic Sprinkler System:				
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants:				
	A	Size of riser/down-comer	N/A	N/A	N/A
	B	Number of hydrants per floor	N/A	N/A	N/A
	C	Hose box	N/A	N/A	N/A
12	Yard Hydrants:				
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13	Pumping Arrangements:				
1	Ground level				
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
2	Terrace Level				
	A	Discharge of pump	220 LPM	220 LPM	MR
	B	Head of the pump	40 m	40 m	MR
	C	Power supply	Required	Provided	MR
	D	Auto starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting:			
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	2,500 liters.	2,500 liters.	MR
15	Exit Signage:	Required	Provided	MR
16	Provision of Lifts:			
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17	Standby Power Supply:	N/A	N/A	N/A
18	Refuge Area:			
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19	Fire Control Room:			
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection system was randomly checked and tested and was found functional at the time of inspection.




Keeping In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules of Directorate of Education the FSC issued vide letter no. F6/MS/DFS/2006/2546 dated 15/09/2006, renewal under Rule 35 (6) of the Delhi Fire Service rules 2010, is recommended to be renewed.


16/4/2025

Signature of the Inspecting Officer
Name: - Yashwant Singh Meena
Designation: - ADO (Laxmi Nagar)

~~D.O/EAST~~

DFA base.


Dy CFO (NDZ)
C.F.O.

Director

ADO

P.T-0