



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/WZ/Hospital/2025/270

Dated: 11/06/2025

To,

Dr. Ajay Kumar Gupta (AMS (A)/HOO,
Dr. B. R Ambedkar Hospital Complex,
Govt. of N.C.T. Delhi, Sec-06, Rohini,
Delhi-110085.

Sub: Request for Fire Audit in r/o Dr. B. R Ambedkar Hospital, Sec-06, Rohini, Delhi-110085.

Sir,

This is in refer to your letter No. F2 (11)/PWD/Fire Safety/BSAH/2024/5986-91 dated 29.03.2025 received through outdoor diary no. 245 dated 04.04.2025 on the subject cited above. In this connection it is to inform you that the building premises has been visited by the officers concerned of this department on **24.05.2025** in presence of **Dr. Pradeep Sharma, Dy. MS & Mr. Iqbal, J. E** and observed that the Hospital is not yet complied with the condition no. 8 of previous FSC issued vide letter no. 109 dated 14.03.2022 and your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due following additional shortcomings;

1. Alternate exits on all floors of ward block found permanently locked and filled with storage material and condemned items/ equipment.
2. Sprinkler found missing in whole central block.
3. FCD closer found damaged in many areas.
4. No Fire Safety officer found appointed under section 2q (g) being hospital building more than 500 beds despite many follow ups.
5. Smoke management system is not sufficient and required to be reviewed with certified consultant and available smoke management system was not in auto mode.
6. Hose-reel length is not found accessible in all the areas, therefore, length of hose-reel is required to be increased and one additional hose is required to be provided in hose-boxes.
7. Manual operated electrical Alarm system found non operation in some areas.

In this regard as stipulated in sub Rule 35 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "I" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours Faithfully

(Virendra Singh)
Chief Fire Officer