



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F.6/DFS/MS/School/2025/SZ/677

Dated: 22 / 08 / 2025

To

Sh. Girijesh Kr. Mishra (Principal),  
Dr. B.R. Ambedkar School of Specialized Excellence,  
Sector 6, Dwarka, New Delhi-110075

Sub: **Renewal of Fire Safety Certificate in r/o Dr. B.R. Ambedkar School of Specialized Excellence, Sector 6, Dwarka, New Delhi-110075**


Sir,

This has reference to your letter No. SOSE/DWK/S-6/2025/54 dated 15/07/2025, received in this department vide outdoor diary No. 3997 dated 22/07/2025. In this connection, it is to inform you that the premise was inspected by the concerned officer of this department on 07/08/2025 in the presence of Smt. Sonal Mittal (Teacher). During course of inspection, **the shortcomings observed are as below.**

1. Hose-reel hose found non-functional, nozzle removed.
2. The terrace level fire pump found non-functional.
3. Overhead water storage exclusive for fire-fighting found empty.
4. Exit signage found removed at some places.

In view of the above, application for **renewal of fire safety certificate cannot be considered at this stage**. You are requested to rectify the shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

  
21/08/2025  
(Virendra Singh)  
Chief Fire Officer  
Delhi Fire Service  
ofc

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.