



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001**

C-76

No.F.6/DFS/MS/NDZ/GH/2025/ 149

Dated: 03/04/2025

To,  
The Joint Commissioner of Police (Lic.),  
1<sup>st</sup> floor Police Station Defence Colony,  
New Delhi

**Subject:-Regarding renewal of Fire Safety Certificate in r/o M/s Dream Land Deluxe Guest House  
Located at 8186/6, Multani, Dhanda, Pahar Ganj, New Delhi-110055.**

Sir,

This has reference to MCD application ID No. 2025030402739 dated 04/03/2025 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department have carried out the inspection of the above mentioned guest house from fire safety point of view in presence of **Mr. Amit Aroara** on dated 24/03/2025. The Guest house is running <sup>at</sup> ground to third floor and building comprised of ground plus four upper floors (4<sup>th</sup> floor closed). The following shortcomings was observed during the time of inspection.

1. First-Aid Hose reels are provided but not functional.
2. Terrace pump is provided but not functional.
3. An overhead water tank capacity 2,500 shall be required exclusive for fire fighting.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

R. 293