



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/WZ/2026/ 490

Dated: - 19/05/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Dr. S.P.M. Civic Centre, JL Nehru Marg,
New Delhi -110002.

Sub.: - Regarding renewal of Fire Safety Certificate in respect Dream Palace (A Unit of JMD Enterprises), located at Plot No. 7259, Prem Nagar, Shakti Nagar, Delhi-110007.


Sir,

This has reference to online application no. 2026041705231 dated 17/04/2026 on the subject cited above. In this connection, it is to inform you that the said building was re-inspected by the officers concerned of this department on 05/05/2026 in the presence of Sh. Shubham Aggarwal. During inspection, it was observed that the above said building is comprised of ground + 02 upper floors but banquet hall is running at ground + 01 upper floor only. After inspection, the following shortcoming were observed: -


1. Fire check door found removed.
2. Overhead water storage tank capacity of 10,000 ltrs. is provided against the required capacity of 20,000 ltrs.

In view of the above shortcomings, the application for renewal of Fire Safety Certificate cannot be considered at this stage & **rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


19/05/26

(S.K. Dua)
Chief Fire Officer
Delhi Fire Service



Copy to: -

1. The Authorized Signatory, Dream Palace (A Unit of JMD Enterprises), located at Plot No. 7259, Prem Nagar, Shakti Nagar, Delhi-110007.