



c 8

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/CC/55

Dated: 16/05/2025

To

The Authorized Signatory
Drishti IAS (A Unit of VDK Eduvenues Pvt. LTD.,)
Plot No-26, Block-34, Pusa Road, Karol Bagh, Delhi-05.

Sub: - Regarding issuance of Fire Safety Certificate in r/o Drishti IAS (A Unit of VDK Eduvenues Pvt. LTD.,) at Plot No-26, Block-34, Pusa Road, Karol Bagh, Delhi-110005.

Sir,

Please refer to your online ID No- 70000104 dated 23/04/2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officers concerned of this department on 06/05/2025 to verify the fire safety arrangements installed in the building. At the time of inspection Sh. Rohit Dalal (Manager) was also present at site. During the course of the inspection it was observed that the building is comprised of basement, ground & 03 upper floors but coaching center is running at first, second & third floor only. Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

1. There are two staircase is provided having width of 1.40m & 1.30m against the requirement of 1.50m.
2. The alternate staircase exits are passing through occupied area, needs to be separated.
3. Fire check doors are not provided in staircase.
4. Sealing of electrical shafts is not properly sealed.
5. Standby power supply is not provided.
6. Staircases required are to be segregated from basement at ground floor level.
7. Other rooms & offices partition by ordinary wooden board required replaced by fire rated wall.
8. Electrical panel installed inside the corridor needs to be removed/shifted in a safer place/out the exit corridor.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the abovementioned shortcomings under intimation to this department; till such time running of educational building (coaching centre) is at your own risk & responsibility.

Yours faithfully

(Atul Garg)

Director

Ph:-011-23414000

Copy to:-

1. The Commissioner, Municipal Corporation of Delhi, Civic Centre, New Delhi: with a request to ensure the occupancy as detailed above.